

BEFORE THE IDAHO PUBLIC UTILITIES COMMISSION

IN THE MATTER OF IDAHO POWER)
COMPANY'S APPLICATION FOR) CASE NO. IPC-E-20-30
AUTHORITY TO ESTABLISH TARIFF)
SCHEDULE 68, INTERCONNECTIONS TO)
CUSTOMER DISTRIBUTED ENERGY)
RESOURCES)

IDAHO POWER COMPANY

DIRECT TESTIMONY

OF

Jared L. Ellsworth

1 Q. Please state your name, business address, and
2 present position with Idaho Power Company ("Idaho Power" or
3 "Company").

4 A. My name is Jared L. Ellsworth. My business
5 address is 1221 West Idaho Street, Boise, Idaho 83702. I
6 am employed by Idaho Power as the Transmission,
7 Distribution & Resource Planning Director for the Planning,
8 Engineering & Construction Department.

9 Q. Please describe your educational background.

10 A. I graduated in 2004 and 2010 from the
11 University of Idaho in Moscow, Idaho, receiving a Bachelor
12 of Science Degree and Master of Engineering Degree in
13 Electrical Engineering, respectively. I am a licensed
14 professional engineer in the State of Idaho.

15 Q. Please describe your work experience with
16 Idaho Power.

17 A. In 2004, I was hired as a Distribution
18 Planning engineer in the Company's Delivery Planning
19 department. My principal responsibilities included
20 developing distribution circuit, substation, and sub-
21 transmission projects to meet growth needs primarily
22 related to equipment capacity and voltage delivered to the
23 customer meter. In 2007, I moved into the System Planning
24 department, where my principal responsibilities included
25 planning for bulk high-voltage transmission and substation

1 projects, generation interconnection projects, and NERC
2 reliability compliance standards. I transitioned into the
3 Transmission Policy & Development group with a similar
4 role, and in 2013, I spent a year cross-training with the
5 Company's Load Serving Operations group. In 2014, I was
6 promoted to Engineering Leader of the Transmission Policy &
7 Development department and assumed leadership of the System
8 Planning group in 2018. In early 2020, I was promoted into
9 my current role as the Transmission, Distribution and
10 Resource Planning Director. I am currently responsible for
11 the planning of the Company's wires and resources to
12 continue to provide customers with cost-effective and
13 reliable electrical service.

14 Q. How is your testimony organized?

15 A. I will provide a general overview of the
16 Company's electrical system and how customers with
17 Distributed Energy Resources ("DER" or "DERs") utilize the
18 Company's distribution system. I will then describe the
19 Company's request to implement the functionality of smart
20 inverters in accordance with Commission Order No. 34046
21 issued in Case No. IPC-E-17-13. Next, I will explain the
22 Company's proposed interconnection requirements for
23 customers seeking to interconnect a non-exporting system to
24 meet a portion of their electricity needs while
25 simultaneously maintaining an electrical connection to the


1 grid ("in Parallel"). Finally, I will provide an overview
2 of the rationale for the Company's proposed process as it
3 relates to interconnecting energy storage devices.

4 **I. IDAHO POWER'S GRID**

5 Q. What is meant by the term "the grid"?

6 A. The grid, in this context, is the electric
7 power system, including the generation, transformation,
8 transmission, distribution, and delivery of energy in the
9 form of electricity to customers.

10 **Figure 1: The Grid**



11
12 Generation converts energy contained in reservoirs,
13 fossil fuels, wind, geothermal wells, or solar rays to
14 electricity. Generation stations are often located remote
15 from customers' point of use; therefore, the electricity is
16 transformed to extremely high voltages to reduce electrical
17 losses and moved on transmission lines over long distances.
18 Once the electricity is delivered to communities, it is
19 transformed to a lower voltage at substations and
20 distributed through the local community on distribution

1 lines. A final stage of transformation is used to reduce
2 voltage to deliver electricity to customer's homes.

3 Q. Which services does the grid offer Idaho
4 Power's customers?

5 A. The grid offers reliable and dependable
6 electricity delivery across large regions in nearly the
7 instantaneous time of a customer's demand. The grid also
8 provides flexibility by allowing the utility access to a
9 diverse portfolio of resources for power generation, even
10 if those resources are located vast distances from where
11 the power is needed.

12 Q. What functions does Idaho Power perform in
13 order to maintain a safe and reliable distribution system
14 and grid?

15 A. In order to provide safe and reliable energy
16 on demand, Idaho Power must perform the following
17 functions: voltage control, system protection, scheduling,
18 dispatching, and load balancing. These functions are
19 commonly referred to, and collectively known as ancillary
20 services.

21 Q. How does Idaho Power control voltage to
22 maintain a safe and reliable distribution system and grid?

23 A. Voltage control is achieved by managing the
24 voltage throughout the grid at the generator, transmission
25 system, and distribution system. The voltage regulating

1 devices control the voltage output of the generators to
2 match the voltage requirements established by personnel
3 within the Company's dispatch control center ("System
4 Operator"). At the substations, System Operators also
5 remotely switch substation capacitors and inductors to
6 raise and lower the transmission voltage, respectively.
7 Automatic voltage management occurs at the distribution
8 substation transformers with voltage control based on load,
9 known as load tap changers. For longer distribution
10 circuits, distribution regulators can be added away from
11 the substation for additional voltage control. Additional
12 automatic control signals are sent to switched distribution
13 circuit capacitors based on substation transformer loading.
14 Finally, voltage control occurs at substations that service
15 large commercial and industrial customers.

16 Q. Does the distribution system provide other
17 services that are specific to a customer with a DER?

18 A. Yes. The grid provides several services for
19 customers with DERs, but most specific to the scope of this
20 case, the distribution system enables inverter operation.

21 Q. What is an inverter?

22 A. An inverter is a power electronics device that
23 converts direct current ("DC") electricity into alternating
24 current ("AC") electricity. Inverters are used in both
25 off-grid and on-grid applications.

1 Q. What types of DERs require an inverter?

2 A. Any DER that produces DC energy requires an
3 inverter. An inverter is required for customers who
4 install a solar photovoltaic ("PV") generation system or an
5 energy storage device because solar panels and batteries
6 produce DC electricity, but home appliances require AC
7 power.

8 Q. How does Idaho Power define a Distributed
9 Energy Resource?

10 A. In Schedule 68, Interconnections to Customer
11 Distributed Energy Resources ("Schedule 68"), included as
12 Attachment No. 1 to the Application, the Company proposes
13 to define a DER as a source of electric power that is not
14 directly connected to the bulk power system. For purposes
15 of administering the proposed Schedule 68, a DER is any
16 combination of a generation facility or an energy storage
17 device connected in Parallel to Idaho Power's system.

18 Q. How does the grid enable inverter operation?

19 A. The majority of inverter-based systems
20 connected to Idaho Power's grid are considered "on-grid"
21 systems. For on-grid systems, the DC electricity generated
22 by the solar PV system is sent directly to an on-grid
23 inverter, which converts the electricity to AC for use by
24 the customer or sent to the grid. Without the grid, the
25 customer's generation system would not operate because

1 these on-grid inverters require an AC voltage grid
2 connection; without this connection, the inverter would not
3 be able to develop voltage or deliver energy. In other
4 words, the grid must be present for customers with on-grid
5 inverters to operate their systems. For the purposes of my
6 testimony, the discussion regarding inverters will be
7 specific to on-grid inverters.

8 **II. IMPACTS OF DER ON IDAHO POWER'S DISTRIBUTION SYSTEM**

9 Q. Please describe a typical distribution
10 circuit.

11 A. Historically, the distribution system could be
12 characterized as a downhill flow of power from electrical
13 substations, across distribution circuits, to customers.
14 Absent DERs, power comes from centralized generators
15 through the transmission system, and the distribution
16 substation regulates the voltage of distribution circuits
17 to deliver energy to customers. As energy travels across
18 the distribution circuit further from the distribution
19 substation, it is delivered at reducing amounts of voltage.
20 American National Standards Institute ("ANSI") standard
21 C84.1 Range A specifies that voltage provided to customers
22 must be in the range of plus or minus five percent of the
23 nominal voltage, i.e., 0.95 - 1.05 per unit ("pu").

24 Q. How do DERs affect distribution system
25 operations?

1 A. DERs add a two-way power flow dynamic to the
2 distribution system, so the historical downhill flow of
3 power may no longer apply. In most installations, this
4 dynamic is inconsequential; however, there are cases where
5 DERs can negatively impact the performance of a
6 distribution circuit. Two such cases are (1) voltage rise
7 causing high voltage and (2) voltage deviations.

8 Q. Please describe what you mean by the term
9 "voltage rise" that may be caused by DER systems.

10 A. Voltage rise occurs when customer generation
11 exceeds customer demand, and power flows back toward the
12 substation transformer.

13 ANSI standard C84.1 Range A specifies that service
14 voltage be delivered to customers within a voltage range of
15 0.95 to 1.05 of nominal voltage. A typical voltage profile
16 for a distribution circuit begins with a maximum voltage,
17 approximately 1.03 pu, at the distribution substation
18 transformer, and voltage will reduce with the distance from
19 the substation. For distribution circuits with high
20 penetrations of customer-owned DERs, the 0.02 pu difference
21 between the 1.03 at the distribution substation, and the
22 1.05 ANSI Range A maximum voltage, can provide challenges
23 in integration.

24 Q. Does the Company typically investigate
25 voltage rise for customer generation applications?

1 A. Yes. The Company has studied this issue
2 frequently with the Public Utility Regulatory Policies Act
3 ("PURPA") projects connecting to the distribution system.
4 The Company also monitors other utility jurisdictions with
5 higher penetrations of DERs and voltage rise. Voltage
6 rise, in particular, is one of the issues that can be
7 addressed through smart inverters.

8 Q. What are typical means to address voltage
9 rise?

10 A. Voltage rise is a function of the conductor
11 size between the generation and the substation. One
12 solution to reduce the voltage rise is to upgrade the
13 conductor with a larger size. This solution is generally an
14 expensive option.

15 Another solution is to change the settings on the
16 voltage regulator to hold the voltage lower and allow for
17 reverse power flow. This solution is dependent on the
18 distribution configuration and will not work in all
19 situations.

20 The third option is to use smart inverter settings
21 for reactive power control functions. This is the most
22 economical solution.

23 Q. Please describe what you mean by "voltage
24 deviations" that may be caused by solar PV.

1 A. Distribution circuits have devices such as
2 load tap changers, regulators, and shunt capacitors, that
3 are installed to manage the voltage at various points on
4 the distribution circuit. These devices respond to voltage
5 changes over a few seconds. The output from a solar PV
6 system changes more rapidly than can be managed by the
7 distribution devices, impacting other customers in the near
8 proximity.

9 Q. Why would a reduction of voltage deviation, a
10 power quality issue, be the responsibility of the customer
11 with a DER?

12 A. In most cases, it is the customer with a DER
13 that creates the voltage deviation, especially in locations
14 with high levels of penetration. Section 4 of Idaho
15 Power's Rule K governing Customer's Load and Operations
16 states "[t]he Customer is solely responsible for the
17 selection, installation, and maintenance of all electrical
18 equipment and wiring (other than the Company's meters and
19 apparatus) on the load side of the Point of Delivery." It
20 is also the customer with a DER that can cost-effectively
21 mitigate the deviation through the installation of a smart
22 inverter. The alternative would be more costly
23 distribution system upgrades required to allow continued or
24 expanded operation of the customer-generators.

1 **III. REQUEST TO IMPLEMENT SMART INVERTER FUNCTIONALITY**

2 Q. What is a smart inverter?

3 A. A smart inverter is an inverter that provides
4 configurable functions beyond the conversion of DC to AC.
5 A few of the features are voltage/reactive power control,
6 anti-islanding, monitoring, and remote communication.

7 Q. Does the Company currently require that
8 customers who install an inverter-based DER interconnect to
9 the grid using a smart inverter(s)?

10 A. No. Section 2 of the current Schedule 72,
11 Interconnections to Non-Utility Generation ("Schedule 72")
12 found in Attachment Nos. 2 and 3 to the Application,
13 requires that on-grid inverters have either a certification
14 with Underwriters Laboratories *Standard for Inverters,*
15 *Converters, Controllers and Interconnection System*
16 *Equipment for Use with Distributed Energy Resources* UL 1741
17 ("UL 1741"), Institute of Electrical and Electronic
18 Engineers *Interconnecting Distributed Resources with*
19 *Electric Power Systems* Standard 1547 ("IEEE 1547") or be
20 subject to third-party testing performed at the customer's
21 expense.

22 Q. What is the Company recommending in this
23 filing regarding smart inverters?

24 A. The Company is requesting authorization to
25 adopt the revised IEEE standards in compliance with Order

1 No. 34047 issued in Case No. IPC-E-17-13. This filing
2 seeks to include the language in the newly proposed
3 Schedule 68, to require that customers with DERs install a
4 smart inverter that meets the requirements defined in the
5 revised IEEE standards.

6 Q. What is the purpose of the IEEE 1547 and
7 1547.1 Standards?

8 A. The IEEE DER interconnection standards (IEEE
9 1547 and IEEE 1547.1) comprise the industry's benchmark and
10 definitively establish the functional requirements for the
11 proper interconnection of DERs within an Area Electric
12 Power System (the utility). IEEE 1547 specifies the
13 functional requirements for interconnection, including
14 design, production, and installation commissioning
15 evaluation. IEEE 1547.1 specifies the equipment
16 conformance test and evaluation procedures.

17 Q. What is the purpose of the adjustable smart
18 inverter variables?

19 A. The smart inverter variables are adjusted to
20 set the normal operating performance categories (Category A
21 or B) and abnormal voltage and ride-through operating
22 performance categories (Category I, II, or III).

23 Q. What smart inverter functionality does the
24 Company propose requiring to maintain normal operating
25 voltage within the acceptable range?

1 A. The Company proposes voltage operational
2 guidelines for inverter-based DERs to be set for normal
3 operating performance Category B. The reactive power
4 control setting will be a voltage-reactive function with a
5 voltage dead band between 0.98 and 1.03 pu. When the
6 voltage falls below the dead band, 0.98 pu, the volt-ampere
7 reactive ("var") requirements will go from 0 to a maximum
8 var requirement of 44 percent of nameplate kilo-volt-ampere
9 ("kVA") injecting at 0.92 pu. When the voltage rises above
10 the dead band, 1.03 pu, the var requirement will go from 0
11 to a maximum of 44 percent of nameplate kVA absorbing at
12 1.06 pu.

13 Q. Why did the company select the 0.98 to 1.03
14 pu dead band?

15 A. The Company selected the 0.98 to 1.03 pu
16 dead band to maximize the amount of time inverter-based
17 DERs spend within the dead band, in other words, operating
18 at unity power factor, while still allowing for voltage
19 support during times of need.

20 Q. Why is the Company recommending minimum
21 (0.92 pu) and maximum (1.06 pu) voltage settings outside of
22 the ANSI C84.1 Range A 0.95 to 1.05 pu service voltage?

23 A. The 0.92 and 1.06 pu voltages represent
24 approximations to ANSI standard C84.1 Range B. Range B
25 specifies a wider allowable service voltage range to

1 customers; however, service voltages outside the 0.95 to
2 1.05 Range A limits should be infrequent, per the standard.
3 These lower and higher limits in the smart inverters allow
4 for var support over a wider range of voltages and ensure
5 the need to supply maximum var support, injecting or
6 absorbing, will be infrequent.

7 Q. What abnormal voltage and ride-through
8 operating requirements does the Company propose?

9 A. The Company proposes that for abnormal voltage
10 events and ride-through capability, inverter-based DERs be
11 set to Category III.

12 Q. Did the Company consider requesting additional
13 smart inverter functionalities to be implemented?

14 A. Yes, but the Company decided not to request
15 additional smart inverter functionality requirements at
16 this time. With the current level of DER penetration on
17 its system, these proposed settings should provide the
18 necessary voltage management capability. The Company
19 recommends all other smart inverter settings be consistent
20 with the most recently approved IEEE 1547 standard
21 (currently IEEE 1547-2018) default settings.

22 Q. Will smart inverters reduce solar PV system
23 efficiencies and/or increase costs for customers?

24 A. Any impact will be negligible. As
25 previously mentioned, the Company is proposing the smart

1 inverters have a voltage-reactive function reactive power
2 control setting with a voltage dead band between 0.98 and
3 1.03 pu. Distribution circuit operation outside of this
4 dead band will be uncommon. Absorbing or providing vars
5 when outside of the dead band will require little to no
6 reduction in the production of the PV Solar system.

7 The alternative would be more costly distribution
8 system upgrades to allow the operation of the DER without
9 on-site var/voltage support.

10 Q. What customer generators will be required to
11 install a smart inverter?

12 A. The Company requests prospective customers
13 that submit an application on or after the effective date
14 of Schedule 68 comply with the smart inverter standard.

15 Q. Will customers with existing generation be
16 required to retrofit their installations to comply with the
17 new standard?

18 A. No. However, if a customer replaces an
19 inverter, they would be required to install an inverter
20 that is compliant with the terms of Schedule 68, or a
21 successor schedule, in place at that time.

22 **IV. CUSTOMER GENERATION NON-EXPORT OPTION**

23 Q. What is the Company proposing as it relates to
24 a customer generator that does not export to the grid?

1 A. The Company is requesting to implement
2 standard interconnection requirements for customers who
3 seek to install DERs but who do not intend to export excess
4 net energy or do not wish to take service under Schedule 6,
5 Residential Service On-Site Generation ("Schedule 6"),
6 Schedule 8, Small General Service On-Site Generation
7 ("Schedule 8") or Schedule 84, Customer Energy Production
8 Net Metering Service ("Schedule 84").

9 Q. Does the Company have customers who have
10 interconnected generation in Parallel without taking
11 service under Schedule 6, 8, or 84?

12 A. Yes. I am aware of a few instances where
13 commercial or industrial ("C&I") customers have
14 interconnected either combined heat and power ("CHP") or
15 solar PV systems behind-the-meter, and in Parallel with the
16 Company's system, but whose request did not align with the
17 requirements contained within Schedule 84. Some of those
18 customers take service under the Company's Schedule 45,
19 Standby Service ("Schedule 45"), but at least one opted not
20 to take Schedule 45 service. I am aware of other customers
21 who have inquired about requirements for DERs that exceed
22 the limitations contained within Schedule 84, but who do
23 not desire to export excess net energy to the Company.

24 Q. What interconnection requirements did the
25 Company require in those cases?

1 A. In the cases I am aware of, the customers
2 contacted the Company to determine whether any specific
3 interconnection requirements were necessary. The Company
4 studied each case independently to determine whether
5 Company-furnished interconnection facilities would be
6 necessary or whether the customer-furnished interconnection
7 provided adequate system protection, metering, and
8 communications equipment.

9 Q. Does Schedule 45 contain requirements for
10 interconnection facilities?

11 A. Yes. Schedule 45 states:

12 Parallel operations will only be
13 authorized by the terms of the Uniform
14 Standby Service Agreement with the
15 Customer. At the Company's discretion,
16 the Company will install a system
17 protection package at the Customer's
18 expense prior to the start of parallel
19 operations. The Customer will also pay
20 a Maintenance Charge of 0.59 percent per
21 month times the investment in the
22 protection package.

23
24 Q. If the Company has interconnected a few
25 customers on a case-by-case basis, why does the Company
26 believe it is now necessary to have requirements outlined
27 in a tariff schedule?

28 A. The instances I mentioned have all
29 interconnected in approximately the last two to three
30 years, but the Company has fielded multiple requests more
31 recently from customers desiring this type of service.

1 Having these requirements defined in the tariff will assist
2 the Company's representatives, installers, and customers,
3 alike who may be involved in discussions regarding
4 interconnecting generation in this manner and will ensure
5 consistent treatment across the service area.

6 Q. What interconnection requirements does the
7 Company propose for non-export customers?

8 A. The Company's proposal would require customers
9 intending to interconnect a non-exporting system in
10 Parallel to the Company's system to submit an application
11 and complete the Customer Generator Interconnection Process
12 set forth in the proposed Schedule 68. The same general
13 requirements would apply to net metering exporting systems
14 and non-exporting systems, including disconnection
15 equipment, metering equipment, and smart inverter
16 requirements. For non-exporting systems under 3 megavolt-
17 ampere ("MVA") total nameplate capacity, the application
18 process will also generally be the same as those for
19 exporting systems.

20 The Company has included additional interconnection
21 requirements specific to non-exporting systems in Sections
22 3 and 4 of Schedule 68. Non-exporting systems would be
23 required to incorporate one of three listed non-export
24 control system options: (1) advanced functionality, (2)
25 reverse power protection, or (3) minimum power protection.

1 Q. What is an advanced functionality non-export
2 control system?

3 A. The use of an internal transfer relay, energy
4 management system, or other customer facility hardware or
5 software system(s) may be used to ensure power is never
6 exported across the interconnection point. Inverter-based
7 generation technologies, such as solar PV or energy storage
8 devices, are particularly likely to utilize this control
9 system. If inverter-based, the generating facility must
10 utilize smart inverters as defined in Schedule 68.

11 As described in Schedule 68, the non-exporting
12 system must monitor the total inadvertent export, and the
13 DER must disconnect from the Company's distribution system
14 or halt energy production within two seconds after the
15 period of continuous inadvertent export exceeds 30 seconds.
16 The non-exporting system must enter a safe operating mode
17 where inadvertent export will not occur as a result of a
18 failure of the control or inverter system for more than 30
19 seconds, which results in loss of control signal, loss of
20 control power or single component failure or related
21 control sensing of the control circuitry.

22 Q. What is a reverse power protection non-export
23 control system?

24 A. To ensure power is never exported, a reverse
25 power relay protective function must be implemented at the

1 interconnection point. As described in Schedule 68, the
2 default setting for this protection equipment shall be 0.1
3 percent (export) of the non-exporting systems total maximum
4 nameplate capacity, measured in terms of either kVA or MVA,
5 with a maximum two-second time delay.

6 Q. What is a minimum power protection non-export
7 control system?

8 A. To ensure at least a minimum amount of power
9 is imported at all times, and therefore, that power is not
10 exported, an under-power protective function may be
11 implemented at the interconnection point. As set forth in
12 Schedule 68, the default setting for this non-export
13 control system shall be five percent (import) of the non-
14 exporting systems total maximum nameplate capacity (kVA or
15 MVA), with a maximum two-second time delay.

16 Q. Do you believe these requirements will be
17 burdensome for customers seeking to interconnect non-
18 exporting systems?

19 A. No. Approximately 99 percent of active net
20 metering systems on Schedule 6, 8, and 84 are inverter-
21 based generation resources. Therefore, the Company would
22 expect that most customers electing for the non-export
23 option would choose to implement the advanced functionality
24 for their non-export control system. As a result, this
25 would not result in an incremental expense for the

1 customer. The other two non-export control options are
2 provided for the rare instances where utilizing the
3 advanced functionality is not a feasible non-export control
4 option.

5 Q. Does the Company propose limiting the total
6 nameplate capacity for non-exporting systems?

7 A. Not in most instances. The net metering
8 service available to exporting commercial, industrial, and
9 irrigation ("CI&I") customers under Schedule 84 is limited
10 to 100 kVA. For CI&I customers with non-exporting systems,
11 the total nameplate capacity would not be limited.
12 Customers on Schedules 1 and 7 would be limited to a total
13 nameplate capacity of 25 kVA.

14 Q. Why is it reasonable to include limitations on
15 Schedules 1 and 7, but not on other service schedules?

16 A. Generally, customers taking service under
17 Schedule 1 or 7 will not have a load large enough to
18 warrant a system larger than 25 kVA to offset their
19 consumption. Further, placing a system cap on Schedule 1
20 and 7 will align with the nameplate capacity limits in
21 Schedule 6 and 8 to allow for customers to transition
22 between the applicable net metering and non-export service
23 schedule.

24 Q. Would CI&I customers be able to transition
25 from a non-export option to Schedule 84?

1 A. If the CI&I customer has a total nameplate
2 capacity of 100 kVA or less, they would have the ability to
3 transition to Schedule 84 in the same manner as a non-
4 exporting customer generator can transition from Schedule 1
5 or 7 to Schedule 6 or 8, respectively.

6 Q. Does the Company propose any other
7 requirements specific to customer generation non-exporting
8 systems?

9 A. Yes. Rotating machines up to 500 kVA total
10 nameplate capacity and inverter-based DERs up to 3 MVA may
11 not require additional Company-furnished protection
12 equipment but will be evaluated on a case-by-case basis.
13 For systems 3 MVA or larger, the Company will require
14 protection equipment, metering, and communications
15 equipment.

16 Q. Why does the Company propose protection
17 equipment requirements for larger systems?

18 A. For rotating machines on the distribution
19 system, these larger systems provide a higher fault current
20 contribution. For inverter-based systems on the
21 distribution system, a DER of 3 MVA or greater represents a
22 significant amount of generation and will make up a minimum
23 of 30 percent of the capacity on a typical distribution
24 circuit. Both types of DERs can affect distribution

1 circuit voltage levels for other customers and can impact
2 operational safety and distribution circuit reliability.

3 The addition of protection equipment provides a
4 means to coordinate distribution circuit protection, such
5 as circuit breakers, reclosers, and fuses.

6 Protection equipment will also be utilized to
7 monitor voltage. A DER 3 MVA or greater has the ability to
8 absorb or supply 1.3+ mega-var of reactive power, which can
9 significantly impact the voltage on the distribution
10 system. Protection equipment for these larger projects
11 will ensure other customers on the feeder are protected
12 from issues that may arise with the DER 3 MVA or greater.

13 Finally, protection equipment provides a means to
14 maintain safety and reliability. Idaho Power operational
15 personnel regularly maintain and operate distribution
16 circuit equipment and must be aware of these larger DER
17 installations when verifying de-energized sections of the
18 circuit, or when transferring load between adjacent
19 distribution circuits.

20 Q. Why does the Company propose a metering and
21 communications equipment requirement for larger DER
22 systems?

23 A. The company is proposing a metering and
24 communications equipment requirement due to the system size
25 and the need for operational visibility to complete

1 critical System Operations functions. Visibility is
2 required for the purposes of scheduling, dispatching, and
3 load balancing.

4 For scheduling, the Company is responsible for
5 forecasting future system loads and resources. Actual data
6 from these customer sites with DERs 3 MVA and larger is
7 critical for maintaining and refining an accurate load and
8 resource forecast.

9 For dispatching, the Company's System Operators
10 frequently move customers from one distribution circuit to
11 another for operational and maintenance purposes. When
12 shifting these customers, System Operators must consider
13 whether ANSI standard C84.1 can continue to be met if the
14 large DER system suddenly reduces output, for example,
15 during a partly-cloudy day.

16 Finally, for load balancing, System Operators
17 maintain a real-time balance between system load and system
18 resources. Real-time information about the output of
19 larger system resources, such as DERs 3 MVA or greater,
20 provides important real-time visibility into what may be
21 causing an area control error deviation, and whether a
22 System Operator should take immediate action, or wait for
23 the clouds to pass.

24 Q. What additional interconnection study
25 requirements does the Company propose specific to non-

1 exporting systems with a total nameplate capacity of 3 MVA
2 and greater?

3 A. The Company proposes that for non-exporting
4 systems with a total nameplate capacity of 3 MVA or
5 greater, the Company will complete additional studies, as
6 needed, at the customer's expense. In addition to the
7 Feasibility Review completed for all DERs, non-exporting
8 systems 3 MVA or greater may also require one or more of
9 the following: Feasibility Study, System Impact Study, and
10 a Facility Study. This process has been modified from the
11 Generation Interconnection Process for PURPA Qualifying
12 Facilities under Schedule 72 and is described in more
13 detail in Section 4 of Schedule 68.

14 At the end of each stage of the study process, the
15 Company will provide the customer generator with an
16 increasingly more refined and detailed report that will
17 present a list of necessary interconnection facilities.
18 The report would also include a non-binding, good faith
19 estimate of the customer generator's cost responsibility
20 for the interconnection facilities. The Company expects
21 the need for a System Impact Study will be rare and
22 reserved for the most complex projects.

23 Q. Why does the Company propose that non-
24 exporting systems 3 MVA or greater complete a full Customer
25 Generator Interconnection Process?

1 A. Due to their size, they can significantly
2 affect the grid's voltage. The process proposed by the
3 Company for these larger non-exporting systems to complete
4 the full Customer Generator Interconnection Process and
5 sign a uniform interconnection agreement recognizes they
6 must have similar performance characteristics compared to
7 any other generation system interconnected under Schedule
8 72.

9 Q. Why must non-exporting systems have similar
10 performance characteristics compared to any other
11 generation system?

12 A. An example of this is during a transient
13 condition that results in extremely low voltage (down 0.88
14 to 0.50 pu); the non-exporting system is required to
15 continue operation for up 20 seconds. The non-exporting
16 system operation, combined with other on-grid DERs, is
17 required to remain connected to avoid a sustained system
18 outage.

19 Q. Will non-exporting systems 3 MVA or greater
20 need to enter Idaho Power's generation interconnection
21 queue?

22 A. No. These DERs are non-exporting systems and,
23 therefore, will not enter the Company's generation
24 interconnection queue.

1 Q. When it is determined that system protection
2 is necessary, how does the Company propose those upgrades
3 will be funded?

4 A. The Company will install a system protection
5 package at the customer's expense, and the customer will
6 pay a maintenance charge of 0.59 percent per month times
7 the investment in the protection package. While general
8 upgrades on the distribution system are funded pursuant to
9 Rule H, in the case of System Protection, the Company
10 proposes the customer will pay the actual installed cost of
11 the system protection equipment. This funding mechanism is
12 similar to what is provided for under the Company's
13 Schedule 45, Standby Service under the Parallel Operations
14 section.

15 Q. Will the Company require a Customer Generator
16 with a non-exporting system to fund upgrades on the
17 Company's distribution system if the non-exporting system
18 total nameplate capacity exceeds the capacity of the local
19 distribution facilities?

20 A. No. The Company initially considered
21 requesting tariff language that would require, for example,
22 a Schedule 6 or 8 non-exporting customer to pay for a
23 transformer upgrade if the system size exceeded that of the
24 transformer. After considering feedback received from the
25 Commission Staff and Idaho Clean Energy Association

1 ("ICEA"), the Company opted to instead propose adding
2 clarifying language to the tariff schedule that would
3 require a customer to replace any damaged equipment if
4 failure of the non-export control system resulted in damage
5 to the Company's system.

6 Q. How does the Company propose to define the
7 failure of the non-export control system?

8 A. Under the language proposed in Schedule 68, an
9 unauthorized inadvertent export would conclusively indicate
10 non-export control system failure. Unauthorized
11 inadvertent export would be defined as the total exports in
12 any 30-day period exceeding three hours of the total
13 nameplate rating. The total nameplate rating is specified
14 on the System Verification Form for a customer generator
15 system. As an example, a 10 kVA AC system would be limited
16 to 30 kWh of export in 30 days. If more than 30 kWh of
17 export occurs, the non-export control system would have
18 failed.

19 Q. What process does the Company propose to
20 mitigate cases of unauthorized inadvertent export?

21 A. The Company would notify the non-exporting
22 customer that their customer generation system has exceeded
23 the inadvertent export limit.

24 For Schedule 1 and Schedule 7 customers, if not
25 rectified within 30 days after receipt of the notification

1 by Idaho Power, the customer can elect to disconnect the
2 non-exporting system from the grid until the issue that
3 caused the export is remedied. An Idaho Power inspection
4 would be required before the non-exporting system could
5 interconnect to the system again. If the customer instead
6 chooses to take service under Schedules 6 or 8, the
7 customer would complete the application process and be
8 placed on Schedule 6 or Schedule 8, as appropriate. If the
9 customer is placed on Schedule 6 or Schedule 8, the
10 customer will be given the option to submit an additional
11 application and be moved back to Schedule 1 or Schedule 7,
12 as appropriate, after 180 days.

13 For customers on Schedules other than Schedule 1 or
14 Schedule 7, upon notification from Idaho Power, the non-
15 exporting system will be disconnected from the grid until
16 the issue that caused the export is remedied. A Company
17 inspection will be required before the non-exporting system
18 can safely interconnect to the Company's system.

19 **V. ENERGY STORAGE DEVICES**

20 Q. Why is the Company proposing to define energy
21 storage devices, such as batteries, in Schedule 68?

22 A. Customer installations of energy storage
23 devices are growing. While energy storage devices are
24 DERs, they are typically installed by customers for the

1 purposes of backup power or time-shifting energy from an
2 on-site generation facility.

3 Establishing criteria in the tariff will best enable
4 the Company, installers, and customers to understand what
5 interconnection requirements are applicable to batteries,
6 just as it does today for generation facilities.

7 Q. Is the Company proposing to include additional
8 interconnection requirements for energy storage devices?

9 A. Under the Company's current proposal, there
10 would be no additional requirements for energy storage
11 devices DC coupled to another generation system (shared
12 inverters). The system size will be determined by the
13 inverter nameplate rating.

14 Energy storage devices which are AC coupled
15 (separate inverters) with a generation facility on Schedule
16 6, 8, or 84 will be treated as a separate DER and require a
17 separate application and interconnection review. The total
18 system size will be determined by the aggregate value of
19 all separate inverter nameplate ratings at the customer's
20 premise.

21 Energy storage devices which are AC coupled
22 (separate inverters) with a non-exporting system or
23 installed on a stand-alone basis would be subject to the
24 provisions of Schedule 68, Section 3 for non-exporting
25 systems. For an energy storage device to not export, it

1 will be required to implement non-export control system
2 Option 1 (Advanced Functionality).

3 Q. Does this conclude your testimony?

4 A. Yes.

5

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

DECLARATION OF Jared L. Ellsworth


I, Jared L. Ellsworth, declare under penalty of perjury under the laws of the state of Idaho:

1. My name is Jared L. Ellsworth. I am employed by Idaho Power Company as the Transmission, Distribution & Resource Planning Director for the Planning, Engineering & Construction Department.

2. To the best of my knowledge, my pre-filed direct testimony and exhibits are true and accurate.

I hereby declare that the above statement is true to the best of my knowledge and belief, and that I understand it is made for use as evidence before the Idaho Public Utilities Commission and is subject to penalty for perjury.

SIGNED this 20th day of July 2020, at Boise, Idaho.



Jared L. Ellsworth