

BEFORE THE IDAHO PUBLIC UTILITIES COMMISSION


IN THE MATTER OF IDAHO POWER) CASE NO. IPC-E-23-01
COMPANY’S APPLICATION FOR A)
CERTIFICATE OF PUBLIC CONVENIENCE) CERTIFICATE NO. 542
AND NECESSITY FOR THE BOARDMAN)
TO HEMINGWAY 500-KV TRANSMISSION)
LINE)
)

IT IS HEREBY CERTIFIED that public convenience and necessity requires and will require Idaho Power Company to construct a 300-mile long, overhead 500-kV high voltage transmission line between the proposed Longhorn Station near Boardman, Oregon, to the existing Hemingway Substation in southwest, Idaho. More specifically, the project requires 298 miles of single-circuit 500-kV transmission line, removal of 12 miles of existing 69-kV transmission line, rebuilding of 0.9 mile of 230-kV transmission line, and rebuilding of 1.1 miles of an existing 138-kV transmission line into a new right-of-way; to exercise all rights and privileges which have been granted to said Idaho Power Company, its successors and assigns by any franchise or permit conferred or hereafter conferred upon said Idaho Power Company, its successors and assigns by any city or village or by any county or by the State of Idaho or by any political subdivision thereof.

This certificate is predicated upon and issued pursuant to the findings and order of this Commission, the same being Order No. 35838 in the above entitled matter made and entered on the 30th day of June, 2023.

///


DATED at Boise, Idaho, this 10th day of August 2023.



ERIC ANDERSON, PRESIDENT




JOHN R. HAMMOND JR., COMMISSIONER



EDWARD LODGE, COMMISSIONER

ATTEST:



Jan Noriyuki
Commission Secretary

I:\Legal\ELECTRIC\IPC-E-23-01 CPCN\ORDERS\IPCE2301_Cert 542_cb.docx