

BEFORE THE IDAHO PUBLIC UTILITIES COMMISSION

IN THE MATTER OF THE APPLICATION)
OF IDAHO POWER COMPANY FOR) CASE NO. IPC-E-23-11
AUTHORITY TO INCREASE ITS RATES)
AND CHARGES FOR ELECTRIC SERVICE)
IN THE STATE OF IDAHO AND FOR)
ASSOCIATED REGULATORY ACCOUNTING)
TREATMENT.)
_____)

IDAHO POWER COMPANY

DIRECT TESTIMONY

OF

MITCH COLBURN

1 Q. Please state your name, business address, and
2 present position with Idaho Power Company ("Idaho Power" or
3 "Company").

4 A. My name is Mitch Colburn. My business address
5 is 1221 West Idaho Street, Boise, Idaho 83702. I am
6 employed by Idaho Power as the Vice President of Planning,
7 Engineering, and Construction.

8 Q. Please describe your educational and
9 professional experience.

10 A. I graduated from the University of Idaho in
11 2006 with a Bachelor of Science degree in Electrical
12 Engineering, Summa Cum Laude. Thereafter, I obtained a
13 Master of Engineering degree in Electrical Engineering from
14 the University of Idaho in 2010 and a Master of Business
15 Administration from Boise State University in 2015. I am a
16 licensed Professional Engineer in the State of Idaho.

17 I have worked at Idaho Power since 2007. Prior to my
18 current role, I served as Director of Engineering and
19 Construction, Director of Resource Planning and Operations,
20 Senior Manager of Transmission & Distribution Strategic
21 Projects, Engineering Leader over 500 kilovolt ("kV") and
22 Joint Projects. I held several engineering roles prior to
23 these leadership roles.

24 Q. What are your duties as Vice President of
25 Planning, Engineering, and Construction?

1 A. I am responsible for an organization of more
2 than 380 employees focused on multiple areas:

3 1) Identifying future electric grid
4 infrastructure requirements,

5 2) Operating and maintaining the electric grid,
6 including the wildfire mitigation program and
7 vegetation management, and

8 3) Designing, engineering, and constructing grid
9 infrastructure projects.

10 Q. What is the purpose of your testimony in this
11 matter?

12 A. The purpose of my testimony is to discuss the
13 investments the Company has made in the electrical grid to
14 ensure the provision of safe, reliable service to
15 customers. My testimony will begin with a discussion of
16 Idaho Power's recent history of reliability and performance
17 that demonstrates a thoughtful approach to grid
18 construction and maintenance. Next, I will detail specific
19 investments included in the Company's 2023 test year that
20 demonstrate the Company's prudent investment in the
21 electrical grid at the transmission and distribution
22 ("T&D") levels. Finally, my testimony will review the
23 Company's wildfire mitigation efforts and associated
24 capital and operation and maintenance ("O&M") expenditures
25 proposed for recovery in this case.

1 Q. What exhibits are you sponsoring?

2 A. I am sponsoring Exhibit Nos. 4 and 5.

3 I. **Reliability and Performance**

4 Q. How is reliability typically measured on the
5 Company's system?

6 A. As discussed in the Direct Testimony of
7 Company Witness Ms. Lisa Grow, Idaho Power primarily uses
8 four indices to measure reliability of the system. To
9 summarize the information provided by Ms. Grow, these four
10 measurements are:

11 SAIFI: System Average Interruption Frequency Index

12 SAIDI: System Average Interruption Duration Index

13 CEMI: Customers Experiencing Multiple Interruptions

14 MAIFI: Momentary Average Interruption Frequency

15 Index

16 Q. Please provide a brief description of each of
17 these measures.

18 A. SAIFI, SAIDI, and CEMI are indices that
19 measure sustained outages. A sustained outage is defined as
20 customers out of power for five minutes or longer. CEMI is
21 typically referred to as "CEMI-1" through "CEMI-6," where
22 CEMI-1 indicates the percentage of customers who had one or
23 more outage, CEMI-2 indicates the percentage of customers
24 who had two or more outages, and so on. MAIFI is an index
25 that measures momentary interruptions. Momentary

1 interruptions are when customers are out of power for fewer
2 than five minutes.

3 Q. Based on these metrics, has Idaho Power
4 demonstrated prudent and reliable operation of the
5 electrical grid?

6 A. Yes. As detailed in Ms. Grow's testimony,
7 Idaho Power's SAIFI metric has improved substantially since
8 2007. On a relative basis, a comparison of Idaho Power's
9 rolling five-year average SAIFI compared to a peer utility
10 group demonstrates that the Company outperformed its peers
11 in each year since 2017.

12 Q. Has Idaho Power shown similar improvement in
13 MAIFI, SAIDI, and CEMI?

14 A. Yes. Each of these metrics has improved across
15 Idaho Power's system for the prior 10-year period, as
16 demonstrated in Figures 1 through 3.

17 //

18 //

19

20

21


22

23


24

25

1 **FIGURE 1**
 2 SAIDI, 2007 THROUGH 2022




3
 4 **FIGURE 2**
 5 MAIFI, 2007 THROUGH 2022




6

1 **FIGURE 3**
 2 CEMI 3 AND CEMI 6, 2007 THROUGH 2022



3
 4 **FIGURE 4**
 5 SAIFI, 2007 THROUGH 2022



6
 7

1 Q. Do these metrics indicate prudent construction
2 and maintenance of the Company's distribution and
3 transmission systems?

4 A. Yes. Idaho Power's reliability metrics
5 reflect a thoughtful approach to construction and
6 maintenance of its T&D systems. Since the completion of the
7 Company's last general rate case ("GRC") in 2011 in Case
8 No. IPC-E-11-08, the Company has placed in service over
9 \$3.3 billion in infrastructure. As I will discuss in my
10 testimony, approximately \$1.6 billion of this total
11 reflects prudent investment in the T&D systems. The
12 corresponding improvement in the Company's reliability
13 metrics over this same period indicates that this
14 investment was prudent to ensure the safe, reliable
15 provision of electric service.

16 **II. Transmission Investments**

17 Q. Please describe how the Company defines the
18 transmission-related portion of the electrical grid.

19 A. Transmission generally describes the bulk or
20 high voltage components of the electrical grid, including
21 stations and high voltage lines typically utilized to
22 transmit large volumes of electricity closer to load
23 centers. On Idaho Power's system, transmission equipment is
24 considered to be facilities at or above 138 kV, with an

1 additional sub-transmission component comprised of
2 facilities at 46 kV and 69 kV.

3 Q. How has transmission-related investment grown
4 since the completion of the 2011 GRC?

5 A. Of the \$3.3 billion in infrastructure placed
6 in service over this period, approximately \$553 million
7 reflects investment in the Company's transmission system.

8 Q. What drives investment in the transmission
9 system?

10 A. Growth and reliability are the primary drivers
11 of the transmission investments reflected in the Company's
12 2023 test year. Growth-related projects typically include
13 either the construction of new transmission facilities or
14 the expanded capacity of existing facilities. Reliability
15 projects typically include the proactive reconstruction or
16 replacement of aging facilities.

17 Q. Please provide examples of growth and
18 reliability needs driving investment in the Company's
19 transmission system between 2012 and 2022.

20 Q. Based on the growth experienced by Idaho Power
21 over this period, investment has been required to ensure
22 reliability on the Company's transmission system. Two
23 projects that demonstrate how growth drives transmission
24 investment are the rebuild of the 59-mile transmission line
25 between the King Substation and the Wood River Substation

1 in the Wood River Valley ("King-Wood River Rebuild") and
2 the upgrade of the 6.8-mile transmission line between the
3 Cloverdale Substation and the Hubbard Substation in the
4 Treasure Valley ("Cloverdale Line Rebuild").

5 Q. What factors led to the King-Wood River
6 Rebuild?

7 A. Growth in the Wood River Valley was causing
8 strain on the regional grid. Specifically, transmission
9 planning studies required¹ by the North American Electric
10 Reliability Corporation ("NERC") and dating back to 2009
11 demonstrated the need for transmission system upgrades to
12 maintain adequate system voltage in the future and avoid
13 needing to shed load for certain system conditions. To
14 comply with NERC standards and to ensure the Company's
15 reliability metrics provided earlier in my testimony did
16 not degrade, investment in the local area transmission
17 system was necessary.

18 Q. What actions did Idaho Power take to ensure
19 the reliability of its transmission system?

20 A. In response to the identified need, Idaho
21 Power rebuilt the line between the King and Wood River
22 substations, upgrading the capacity of the line.
23 Additionally, for enhanced reliability the Company replaced

¹ NERC TPL-001 Reliability Standard (Table 1 - Steady State & Stability Performance).

1 the existing wood structures with steel components. This
2 investment was required to ensure that system reliability
3 was maintained while accommodating growth in the area.

4 Q. Did similar factors lead to the Cloverdale
5 Line Rebuild in the Treasure Valley?

6 A. Yes. Similar factors led to the Cloverdale
7 Line Rebuild, further exemplifying how growth drives the
8 need for investment to maintain a robust, reliable
9 transmission system. In 2015, NERC-required transmission
10 planning studies demonstrated the need for a 230-kV
11 connection between the Hubbard and Cloverdale substations,
12 whereas the existing line was 138 kV. The study showed that
13 growth in the area had resulted in expected loads under
14 certain conditions exceeding emergency equipment rating
15 limits.

16 Q. What actions did Idaho Power take to address
17 the reliability needs identified by this study?

18 A. In response to the growth-driven reliability
19 requirements in the area, Idaho Power upgraded the local-
20 area capacity by replacing the existing 138-kV line with a
21 230-kV circuit, as well as constructing distribution
22 circuits located on the same structures as the 230-kV
23 transmission line. This upgrade reflected a cost-effective
24 solution to meet the requirements of growing load in the

1 Treasure Valley, enhancing and maintaining reliability of
2 the local transmission system.

3 Q. Can you provide an example of transmission
4 investment driven by the Company's proactive approach to
5 aging infrastructure?

6 A. Yes. The Company's work on the Midpoint-to-
7 Borah 345-kV transmission line demonstrates the need to
8 invest in maturing longer-lived assets to ensure ongoing
9 safe and reliable operation of the grid.

10 Q. Please describe the Midpoint-to-Borah
11 transmission line.

12 A. The Midpoint-to-Borah 345-kV transmission line
13 serves as a major component of the Company's bulk
14 transmission system. This line was originally constructed
15 in 1948 and operated at 138 kV, and over the next several
16 decades was modified and improved to its current operating
17 capacity of 345kV. Enhancements to the line over this
18 period included an increase in capacity due to the addition
19 of the Jim Bridger Power Plant, which included the addition
20 of a second conductor, conductor re-configuration on the
21 structures, and adding additional insulation to operate at
22 a higher voltage. However, as the transmission line aged,
23 issues began to arise related to ground clearance and
24 leaning structures.

1 Q. What action was required to address this aging
2 and important component of the Company's bulk transmission
3 system?

4 A. The age and importance of this line warranted
5 complete replacement of the structures from the Midpoint
6 Substation to the Borah Substation. The existing wood-pole
7 structures were replaced with steel-pole structures,
8 remedying the potential structural issues by installing
9 resilient, long-life steel poles.

10 Q. Do the projects you have discussed demonstrate
11 a prudent approach to investment in the Company's
12 transmission system over the last decade, and support the
13 Company's transmission-related rate base included in this
14 case?

15 A. Yes. Over the last decade Idaho Power has
16 invested over \$553 million in its transmission system. As
17 evidenced by the King-Wood River Rebuild and Cloverdale
18 Line Rebuild projects, Idaho Power is constantly evaluating
19 the capacity needs and reliability of its transmission
20 systems, ensuring that the electrical grid is stable and in
21 compliance with NERC standards. As further evidenced by the
22 Midpoint-to-Borah Rebuild, Idaho Power's investments in the
23 transmission system over the last decade reflect a
24 thoughtful, proactive approach to ensuring bulk system
25 reliability. As evidenced by the improving reliability

1 metrics experienced over this same period, these
2 investments were prudently made and in the public interest.

3 **III. Distribution Investments**

4 Q. Please describe how the Company defines the
5 distribution-related portion of the electrical grid.

6 A. Distribution refers to equipment at 34.5 kV
7 and below, including lower voltage lines, substations, and
8 transformers that are typically utilized to provide
9 electricity at the lower voltages required by the majority
10 of end-use customers.

11 Q. How much has distribution-related investment
12 grown since the completion of the 2011 GRC?

13 A. Of the \$3.3 billion in plant placed in service
14 referenced previously in my testimony, approximately \$1.0
15 billion is comprised of investments in the distribution
16 system.

17 Q. What factors contributed to investment in
18 Idaho Power's distribution system over this period?

19 A. Growth in the distribution system can be
20 directly tied to the addition of new customers, as every
21 new customer, regardless of service level, requires some
22 form of additional equipment. In addition, similar to
23 certain components of the Company's generation and
24 transmission systems, Idaho Power has also undertaken a
25 number of key projects to proactively harden its

1 distribution system to maintain and improve reliability in
2 light of aging infrastructure. These investments not only
3 include the proactive replacement of aging infrastructure,
4 but also the improvement of the distribution system through
5 the installation of modern technology.

6 Q. How does growth impact the need for investment
7 on the distribution system?

8 A. Growth impacts the distribution system in
9 several ways. First, the addition of new customers requires
10 new investment - from new service transformers and service
11 drops for every new customer to, once demand reaches
12 certain levels, new substations and lines. Additionally,
13 construction and growth within the Company's service area
14 also result in the need for investment related to facility
15 relocations for road construction and other civil projects.

16 Q. What were the primary growth-related
17 components of distribution investment made over the last
18 decade?

19 A. Growth-related investment in the Company's
20 distribution system consisted primarily of meters,
21 transformers, and other distribution infrastructure in each
22 of the Company's operating regions. In addition to new
23 facilities, Idaho Power spent approximately \$25 million
24 related to the relocation of facilities as the result of
25 road projects in the Company's service area.

1 Q. In addition to serving growth, has Idaho Power
2 undertaken any major initiatives to maintain or improve the
3 reliability of its distribution system?

4 A. Yes. There are two notable initiatives Idaho
5 Power has undertaken to improve the reliability of its
6 distribution system: 1) the replacement of direct-buried
7 underground cable and 2) a grid modernization initiative
8 that encompasses multiple projects.

9 Q. Please describe what is meant by "direct-
10 buried cable."

11 A. Direct-buried cable describes underground
12 distribution cable that was directly buried in the soil
13 with no conduit. The use of direct-buried cable was
14 standard practice in the industry and for Idaho Power up
15 until the mid-1990s.

16 Q. What are the benefits of replacing direct-
17 buried cable with new cable in conduit?

18 A. Replacing the existing direct-buried cable
19 with new cable in conduit improves reliability and lowers
20 future expenses when the cable needs to be replaced.

21 Q. How does the installation of cable with
22 conduit improve reliability?

23 A. Cable in conduit is better protected from
24 impacts related to direct contact with soil and moisture.

1 Consequently, faults are less frequent and cable in conduit
2 is expected to last longer than direct-buried cable.

3 Q. How does the installation of cable in conduit
4 help to lower future expenses when the cable needs to be
5 replaced?

6 A. The installation of conduit allows the Company
7 to replace the cable within the conduit more effectively
8 and cheaply. With conduit in place, the cable can be
9 removed from the conduit and new cable can be installed
10 more efficiently. This will help to eliminate fees and
11 expenses associated with permitting, flagging, landscaping
12 and repaving roads and sidewalks.

13 Q. How far has Idaho Power's underground cable
14 replacement project progressed?

15 A. The underground cable replacement program
16 began in 2012 with completion forecasted for 2035,
17 targeting the replacement of approximately 350,000 feet of
18 direct-buried cable each year until all 7 million feet of
19 direct-buried cable have been replaced. To date, the
20 Company has completed approximately 4 million feet of cable
21 replacement.

22 Q. Please describe the grid modernization
23 initiative.

24 A. The grid modernization initiative is a set of
25 multi-year projects designed to maintain and improve

1 reliability on the Company's electrical grid. This suite of
2 projects replaces and modernizes equipment nearing its end
3 of life and updates the Company's distribution system with
4 modern technology to enhance reliability while keeping
5 costs low.

6 Q. What notable projects comprise grid
7 modernization efforts included in the 2023 test year?

8 A. Two notable projects under the Company's grid
9 modernization initiative are the implementation of a new
10 700-megahertz ("MHz") Field Area Network ("FAN") and
11 replacement of an Automated Capacitor Control ("ACC")
12 system with the development of a new integrated volt-var
13 control ("IVVC") system. The IVVC system and FAN became
14 operational in 2019 and were built out across Idaho Power's
15 service area by 2022.

16 Q. What are the FAN and the IVVC system, and how
17 do they interrelate?

18 A. The 700-MHz FAN serves as the communication
19 backbone for the IVVC system. The 700-MHz FAN is utilized
20 to send and receive secure, reliable wireless
21 communications to and from line devices on Idaho Power's
22 distribution system. This communication supports the
23 gathering of data and control of distribution system
24 devices within the IVVC.

25 Q. How does the IVVC system benefit customers?

1 A. The IVVC system replaced a 22-year-old DOS-
2 based system that was nearing its end of life and was
3 unable to provide for direct and coordinated voltage
4 control offered by more modern systems such as the IVVC
5 system. Replacing the ACC with the IVVC provides the
6 Company with the ability to better control devices and
7 gather data in real-time, allowing the Company to improve
8 power quality and voltage levels, optimize efficiency, and
9 provide visibility and control to engineers and operators
10 to better manage the distribution system.

11 At a high level, the IVVC system provides direct
12 feedback on the status of devices through two-way
13 communication, which reduces the need for seasonal
14 inspections, instead allowing for inspections to focus on
15 alarmed devices. This system is also the foundation for a
16 future fault location, isolation, and service restoration
17 ("FLISR") system. Idaho Power is in the process of
18 installing fault location devices on the distribution
19 system, which is prevalent in the industry.

20 Q. Do these projects demonstrate a prudent
21 approach to investment in the Company's distribution
22 system over the last decade and support the Company's
23 distribution-related rate base included in this case?

24 A. Yes. Idaho Power's thoughtful and proactive
25 approach to investing in its distribution system has

1 resulted in improved reliability metrics over the past
2 decade as detailed earlier in my testimony. In addition to
3 investing to accommodate growth within the Company's
4 service area, Idaho Power invested in initiatives such as
5 underground cable replacement and grid modernization that
6 ensure the distribution system is equipped to provide safe,
7 reliable service to customers now and in the future.

8 **IV. Idaho Power's Wildfire Mitigation Efforts**

9 Q. What total system costs did the Company
10 incur related to wildfire mitigation in 2022?

11 A. As outlined below in Table 1 of my
12 testimony, Idaho Power incurred a systemwide total of
13 \$26,408,743 in wildfire mitigation-related O&M costs in
14 2022. This amount excludes insurance, which is discussed in
15 the Direct Testimony of Company Witness Mr. Brian Buckham.

16 Regarding capital expenditure, Idaho Power placed
17 in service \$12,059,451 in capital projects to support
18 wildfire mitigation in 2021 and 2022. This amount does not
19 include capital depreciation, which is addressed in the
20 Direct Testimony of Company Witness Mr. Matthew Larkin.

21 Capital placed in service for 2021 and 2022 and
22 O&M expenditure for 2022 is detailed in Exhibit No. 4 to my
23 testimony.

1 Q. Are the Company's actual 2022 costs related
2 to wildfire mitigation reflected in the Company's revenue
3 requirement in this case?

4 A. Yes. The costs identified in my testimony
5 are factored into the Company's 2023 test year revenue
6 requirement, as addressed in Mr. Larkin's testimony.
7 Additionally, the treatment and accounting of the
8 Commission's authorized wildfire deferrals are addressed in
9 the Direct Testimony of Company Witness Ms. Paula Jeppsen.

10 The remainder of my testimony in this section will
11 present the Company's implementation of its Wildfire
12 Mitigation Plan ("WMP") and will demonstrate the prudence
13 of the associated costs proposed for recovery in this case.
14 I will focus on costs incurred during 2022, as those costs
15 represent previously deferred amounts proposed for
16 amortization into rates in this case and form the basis for
17 the test year values addressed by Mr. Larkin.


18 Q. Why did Idaho Power develop a WMP?

19 A. Idaho Power is dedicated to safely delivering
20 reliable, affordable energy to its customers. In pursuit of
21 that mission, the Company developed a WMP in response to
22 the increase in frequency and intensity of wildfires seen
23 across the western United States ("US") in recent years.

24 Q. To what extent has wildfire activity increased
25 in the West?

1 A. Since the 1980s, wildfire activity in the US,
2 as measured by acres burned, has more than tripled and,
3 according to the National Interagency Fire Center, western
4 states account for upwards of 95 percent of the acres
5 burned in recent years.² Since 1983, the 10 years with the
6 largest acreage burned have all occurred in the period of
7 2004 through 2022.³

8 **FIGURE 5**
9 TOTAL US ACRES BURNED (1983-2022)



10

11 Q. What has contributed to the growth of western
12 wildfires in recent years?

² Based on the National Interagency Fire Center historical year-end fire statistics by state. <https://www.nifc.gov/fire-information/statistics>

³ Based on the National Interagency Fire Center total wildland fires and acres (1983-2022). <https://www.nifc.gov/fire-information/statistics>
<https://www.nifc.gov/fire-information/statistics/wildfires>

1 A. A variety of factors have contributed to a
2 greater number of destructive wildfires, including climate
3 change, increased human encroachment in wildland areas,
4 historical land management practices, and changes in
5 wildland and forest health, among other factors.

6 Q. How has Idaho Power been affected by the
7 increase of wildfires in the West?

8 A. While Idaho Power has not experienced
9 catastrophic wildfires within its service area at the same
10 level experienced in other western states, such as
11 California and Oregon, millions of acres of rangeland and
12 southern Idaho forests have burned in the last 30 years.⁴

13 In 2022, Idaho had fewer wildfires and acres burned
14 during wildfire season than the previous 20-year average.⁵
15 However, 436,733 acres burned in Idaho during the 2022 fire
16 season, a larger amount than the combined acres burned in
17 Arizona, Colorado, Montana, Nevada, Utah, and Wyoming in
18 2022.⁶

19 Q. What impacts could Idaho Power face because of
20 wildfire?

⁴ Rocky Barker, *70% of S. Idaho's Forests Burned in the Last 30 Years. Think That Will Change? Think Again.*, Idaho Statesman, Oct 4, 2020.

⁵ Based on the National Interagency Fire Center historical year-end fire statistics by state. <https://www.nifc.gov/fire-information/statistics>

⁶ National Interagency Coordination Center Wildland Fire Summary and Statistics Annual Report, 2022. https://www.predictiveservices.nifc.gov/intelligence/2022_statsumm/annual_report_2022.pdf

1 A. Wildfire can create myriad and costly
2 environmental, social, and economic impacts. The magnitude
3 and duration of these impacts depends on a fire's size,
4 severity, and location. Generally, though, wildfire impacts
5 are considered in terms of lives threatened, structures or
6 homes lost or damaged, and damage to natural resources.

7 Specific to Idaho Power, wildfires have the
8 potential to damage or destroy the Company's facilities,
9 impact personnel, and cause significant harm to Idaho
10 Power's customers and the communities in which the Company
11 serves.

12 Q. How has Idaho Power responded to growing
13 wildfire risk?

14 A. As a result of growing and more frequent
15 wildfires in the West, Idaho Power began a proactive effort
16 in 2019 to develop a guiding wildfire mitigation document –
17 the WMP – that would use robust risk analysis to identify
18 areas within the Company's service area exposed to higher
19 levels of wildfire risk. As an action plan for Company
20 operations, the WMP includes best practices for mitigating
21 wildfire risk that guide operational, personnel, and
22 communication practices before, during, and after wildfire
23 season.

24 Q. What are the objectives of the WMP?

1 A. Idaho Power developed the WMP to accomplish
2 two critical objectives: (1) reduce wildfire risk
3 associated with Idaho Power's T&D facilities and associated
4 field operations and (2) improve the resiliency of the
5 Company's T&D system impacted by wildfire events.

6 Q. How many WMPs has the Company developed?

7 A. In December 2022, the Company published its
8 2023 WMP (Exhibit No. 5), the Company's fifth version of
9 the WMP since 2021.

10 Q. Please describe the prior versions of the WMP.

11 A. Version 1 of the WMP was filed with the
12 Commission in January 2021 in Idaho Power's initial
13 wildfire-related cost deferral Application in Case No. IPC-
14 E-21-02. Version 2, dated December 21, 2021, included an
15 expanded cost-benefit analysis discussion, WMP progress and
16 updates, and an introduction to the Company's newly
17 developed Public Safety Power Shutoff ("PSPS") program.
18 Version 3, dated June 28, 2022, included information added
19 to comply with the Public Utility Commission of Oregon's
20 conditions of approval of the Company's 2022 WMP. Version
21 4, filed with the Company's cost deferral Application in
22 Case No. IPC-E-22-27, added Idaho and Oregon specific
23 information and state-specific forecasts of incremental
24 mitigation expenditure. Version 5, the current WMP for the
25 2023 fire season, includes a new executive summary, a

1 review of the 2022 fire season with lessons learned, a
2 forecast of condition for the upcoming fire season, and
3 provides a detailed discussion of 2023 fire season
4 mitigation measures.

5 Q. How will the WMP change from year to year?

6 A. Each year, the Company strives to improve upon
7 previous versions by incorporating new learnings, methods,
8 and feedback from stakeholders, customers, communities,
9 fire experts, and the Company's regulators. Going forward,
10 the Company will file its annual WMP with the Commission,
11 as specified in Order No. 35717.⁷ Moving forward and to
12 reduce confusion, the Company will endeavor to avoid
13 multiple versions of the WMP and, instead, release one plan
14 in advance of each fire season.

15 Q. Please summarize the key elements of the WMP
16 that help meet the Company's wildfire mitigation
17 objectives.

18 A. Idaho Power's WMP includes comprehensive and
19 multi-faceted strategies that are effective at reducing
20 wildfire risk. Key elements of the plan include:

21 • Risk analysis and mapping: Utilizing a risk-based
22 approach for decision making and quantifying wildfire risk
23 throughout the Company's service area.

⁷ Case No. IPC-E-22-27, Order No. 35717, pp. 8-9 (Mar 23, 2023).

1 • Situational awareness: Informing Company
2 operations and practices by incorporating new methods of
3 visual, geographical, and contextual awareness of the
4 environments in which Idaho Power operates, specifically
5 during wildfire season.

6 • Mitigation activities: Expanding and/or enhancing
7 many of the same programs that the Company has carried out
8 over the course of its operating history to mitigate
9 wildfire risk, decrease the likelihood of ignition events,
10 and protect infrastructure from wildfire regardless of
11 where it starts.

12 • Communication: Communicating with and educating
13 customers and the public about wildfire and outage
14 preparedness.

15 • Monitoring and tracking performance: Routine
16 analysis of wildfire mitigation activities to gauge their
17 effectiveness and build continuous improvement and risk
18 reduction over time.

19 Q. How does Idaho Power ensure its WMP is
20 informed by industry best practices?

21 A. Idaho Power recognizes the importance of
22 engaging with federal, state, and local governments as an
23 integral part of deciding on and implementing wildfire
24 mitigation measures. The WMP documents specific activities
25 and forums to engage with key stakeholders to share

1 information, gain feedback, and incorporate lessons
2 learned.

3 Much of Idaho Power's service area extends over land
4 managed by the US Bureau of Land Management ("BLM") and the
5 US Forest Service. As such, the Company engaged with these
6 agencies in the development of the WMP and continues to
7 hold meetings and workshops with them to share information
8 and identify geographic areas and specific mitigation
9 activities that are mutually beneficial.

10 Idaho Power is also a member of the Idaho Fire
11 Board, which was initiated by the US Forest Service.
12 Membership is voluntary and currently includes the Forest
13 Service, BLM, the Federal Emergency Management Agency,
14 Idaho State Lands Department, Idaho Department of
15 Insurance, Idaho Military Division, City of Lewiston, the
16 Nature Conservancy of Idaho, and Idaho Power. This group,
17 like the efforts listed above, is also focused on sharing
18 Idaho wildfire knowledge and best practices for wildfire
19 mitigation.

20 Q. Did Idaho Power consult with other utilities
21 to develop and inform its WMP?

22 A. Yes. Peer utility engagement was crucial in
23 developing the WMP to ensure the Company's efforts are
24 consistent with best practices and aligned with its peers
25 in the region. To inform the initial development of the

1 WMP, Idaho Power participated in multiple workshops with
2 San Diego Gas and Electric, Southern California Edison,
3 Pacific Gas and Electric, Sacramento Municipal Utility
4 District, and PacifiCorp. The Company continues to engage
5 with these utilities to learn about California's evolving
6 practices.

7 In the Pacific Northwest, many utilities work
8 collaboratively to understand and ensure commonality of
9 their respective wildfire plans, while also accounting for
10 the variation in each utility's unique service area. These
11 utilities include Idaho Power, Avista Utilities, Portland
12 General Electric, Rocky Mountain Power, Pacific Power,
13 Chelan County Public Utility District, Puget Sound Energy,
14 NV Energy, Bonneville Power Administration, and
15 NorthWestern Energy.

16 Q. Does Idaho Power participate in any other
17 collaborative efforts to inform and evolve its WMP?

18 A. Yes. Idaho Power is a member of both the
19 Edison Electric Institute ("EEI") and the Western Electric
20 Institute, both of which host workshops and conferences to
21 help members discuss and compare their wildfire plans and
22 mitigation efforts.

23 Additionally, Idaho Power's President and Chief
24 Executive Officer Lisa Grow is an active member of EEI's
25 Electricity Subsector Coordinating Council Wildfire Working

1 Group. This working group partners with the US Department
2 of Energy and other government agencies to collectively
3 minimize wildfire threats and potential impacts nationwide.

4 These industry collaboratives continue to prove
5 valuable for sharing wildfire mitigation best practices and
6 discussing new and existing technology related to wildfire
7 mitigation.

8 ***Wildfire Risk Analysis & Selection of Mitigation Practices***

9 Q. Was a risk-based approach used to determine
10 the type and level of wildfire mitigation needed for Idaho
11 Power's service area?

12 A. Yes. The Company followed a risk-based
13 approach in identifying, analyzing, and selecting wildfire
14 mitigation measures. The Company has integrated the
15 practices and principles detailed in the International
16 Standard ISO 31000, Risk Management Guidelines, to manage
17 wildfire risk and meet the goals and objectives of the WMP.

18 Wildfire risk mitigation is an enterprise-wide
19 effort, and risk reduction practices are integrated into
20 normal business activities and decision making across the
21 Company - from field personnel to executive officers.

22 Q. Please describe the Company's wildfire-based
23 risk framework.

1 A. The Company takes a structured and effective
2 approach to managing wildfire-related risk that includes
3 the following:

- 4 • Identify risk - Recognize new and evolving
5 threats and associated risk;
- 6 • Analyze - Understand new and evolving risk,
7 including likelihood and consequence and any existing
8 controls;
- 9 • Evaluate - Determine whether risk levels can be
10 accepted or should have additional controls in place;
- 11 • Mitigate - Select appropriate risk treatment;
- 12 • Monitor - Continually check and review to
13 determine effectiveness of mitigation practices and
14 protocols; and
- 15 • Communicate and consult- Communicate, educate,
16 and engage with stakeholders, customers, communities, and
17 regulators about the Company's risk-based wildfire
18 mitigation work.

19 Q. What methodology was used to quantify
20 wildfire risk?

21 A. Idaho Power leveraged an external consultant
22 - Reax Engineering - that specializes in assessing and
23 quantifying wildfire risk to determine where wildfire risk
24 is elevated within the Company's service area. The
25 consultant used a risk-based methodology that incorporates

1 weather modeling, wildfire spread modeling, and Monte Carlo
2 simulations, among other modeling techniques.

3 This approach to modeling wildfire risk is not
4 unique to Idaho Power. The California Public Utilities
5 Commission("CPUC") used the same modeling approach – and
6 the same consultant – as part of its development of the
7 CPUC Fire Threat Map. Other utilities in Oregon, Idaho,
8 Nevada, and Utah have utilized similar modeling approaches
9 to identify and quantify wildfire risk.

10 Q. What calculation does the Company use to
11 determine elevated risk areas?

12 A. The Company's wildfire consultant modeled
13 wildfire risk considering a wildfire event's probability
14 multiplied by its potential negative consequences or
15 impacts, should that event occur. Expressed as a formula:

16
$$\textit{Wildfire Risk} = \textit{Fire Probability} \times \textit{Consequence}$$

17 The first term, Fire Probability, is based on fire
18 volume (i.e., spatial integral of fire area and flame
19 length) because rapidly spreading fires are more likely to
20 escape initial containment efforts and become extended
21 fires rather than slowly developing fires. The second term,
22 Consequence, reflects the number of structures (i.e.,
23 homes, businesses, and other man-made structures) that
24 could be impacted by a wildfire.

1 Q. How does this equation translate to elevated
2 risk areas?

3 A. Using the formula noted above, areas of
4 highest wildfire risk will be those in which both Fire
5 Probability and Consequence are elevated. Conversely,
6 combinations of low Fire Probability and elevated
7 Consequence (or elevated Fire Probability but low
8 Consequence) will not typically be areas with highest risk.

9 Detailed discussion of the risk formula, including
10 modeling and model inputs, is provided in Exhibit No. 5.

11 Q. What are the results of the wildfire risk
12 modeling?

13 A. Using the above methodology and risk formula,
14 Idaho Power and its consultant identified specific
15 geographic areas across its service area and transmission
16 corridors. The Company then sorted these areas into tiers –
17 Yellow Risk Zones, reflecting increased risk, and Red Risk
18 Zones, reflecting highest risk. Red Risk Zones – such as
19 those in the Boise foothills and around Payette Lake in
20 McCall – were determined to have the greatest wildfire risk
21 based on the combination of Fire Probability and
22 Consequence, while Yellow Risk Zones have elevated risk but
23 may have reduced Fire Probability and/or Consequence
24 relative to Red Risk Zones.

1 These risk zones are the foundation of Idaho Power's
2 wildfire risk mitigation strategies and are used to
3 prioritize targeted investments, vegetation management
4 work, inspection activities, and situational awareness.

5 Q. How much of the Company's service area is in
6 elevated wildfire risk zones?

7 A. Approximately 7 percent of the Company's
8 overhead distribution and 11 percent of transmission lines
9 are located within wildfire risk zones. These geographical
10 areas include approximately 47,000 customers.

11 Q. Does the Company visualize its elevated risk
12 areas?

13 A. Yes. Based on the wildfire risk analysis,
14 Idaho Power developed a risk map, shown below, that
15 reflects the two tiers of increased wildfire risk within
16 the Company's service area. The map – provided on Idaho
17 Power's website – is available publicly and accessible to
18 Public Safety Partners to educate and inform them about the
19 Company's elevated risk areas.

20

21


22

23

24

25

1 **FIGURE 6**
2 IDAHO POWER WILDFIRE RISK MAP
3



4
5

6 Q. How have these wildfire risk zones informed
7 the Company's wildfire mitigation projects?

8 A. The Company's wildfire mitigation activities
9 are specifically targeted at reducing wildfire risk in
10 elevated risk areas, with Red Risk Zones given priority due
11 to the increased level of risk associated with higher fire
12 probability and potential impact to structures.

13 Q. What types of mitigation activities is the
14 Company pursuing?

15 A. Based on the risk identified in the
16 Company's risk assessment, Idaho Power developed and

1 grouped its wildfire mitigation work into the following
 2 categories: A) quantifying wildland fire risk; B)
 3 situational awareness; C) mitigation associated with field
 4 personnel practices; D) mitigation activities within Idaho
 5 Power's T&D programs; E) enhanced vegetation management; F)
 6 communication; and G) information technology. Idaho Power's
 7 specific activities in these categories, as well as actual
 8 2022 O&M and capital expenditures, are described in the
 9 sections below.

10 **Wildfire Mitigation O&M Expense**

11 Q. Please describe Idaho Power's system O&M
 12 expenses for wildfire mitigation in 2022.

13 A. The table below summarizes Idaho Power's total
 14 systemwide O&M expenses by wildfire mitigation category for
 15 2022:

16 **TABLE 1**
 17 WILDFIRE MITIGATION O&M IN 2022

Wildfire Mitigation Category	Program Activity	2022 Actuals
Quantifying Wildland Fire Risk	Risk Analysis and Map Updates	\$4,125
Situational Awareness	Weather Forecasting - System Development, Support, and Personnel	\$156,201
Mitigation - Field Personnel Practices	Tools/Equipment	\$10,720

Mitigation - Transmission & Distribution Programs	O&M Component of Capital Work	\$898,966
	Annual O&M T&D Patrol	
	Maintenance Repairs	
	Environmental Management Practices	
	T&D Thermography Inspection Mitigation & Personnel	
	Transmission Wood Pole Fire Resistant Wraps - Red Risk Zone	
	Transmission Wood Pole Fire Resistant Wraps - Yellow Risk Zone	
	Wildfire Mitigation Program Manager	
Covered Wire Evaluation - Pilot Program in PSPS Zones		
Enhanced Vegetation Management	Transition to/Maintain 3-Year Vegetation Management Cycle	\$25,151,422
	Enhanced Practices for Distribution Red & Yellow Risk Zones (Pre-Season Patrols/Mitigation, Pole Clearing, Removals, Work, QA)	
	Line Clearing Personnel	
	Vegetation Management Satellite and Aerial Patrols	
Communications	Wildfire/Wildfire Mitigation Communications - Advertisements/Meetings/Other	\$106,779
	PSPS Customer Education/Communication - Advertisements, Bill Inserts/Other	
Information Technology	Communication/Alert Tool development (System set up, outage maps, critical facilities identification)	\$80,531

1

2 **O&M: Quantifying Wildfire Risk**

3 Q. Why did the Company choose to use a consultant
4 to quantify wildfire risk in its service area?

1 A. The Company selected Reax Engineering for its
2 recognized expertise in wildfire risk modeling and fire
3 science. Hiring an outside consultant helped ensure Idaho
4 Power's risk analysis would be developed in a manner
5 consistent with and comparable to peer utilities.

6 Q. Was it prudent for the Company to hire an
7 external consultant to develop the wildfire risk analysis?

8 A. Yes. Hiring an external consultant was a
9 prudent Company decision for two reasons. First, it was
10 more cost effective than hiring additional internal
11 resources with specialized experience in wildland fire
12 behavioral modeling. Second, hiring a nationally recognized
13 consultant provides confidence that the Company's risk
14 areas – the basis for all its wildfire mitigation work—were
15 determined using the best and latest wildfire modeling
16 techniques.

17 Q. How much did the Company spend to quantify
18 wildfire risk in 2022?

19 A. The Company's wildfire risk analysis was first
20 conducted in 2020. Every two years the Company intends to
21 work with Reax Engineering to refine the risk analysis,
22 adjust as warranted, and update its risk maps. In 2022, the
23 Company spent \$4,125 on external consultant activities to
24 update and refine its wildfire risk map.

25 //

1 **O&M: Situational Awareness**

2 Q. What efforts and activities did the Company
3 conduct in 2022 to enhance situational awareness during
4 wildfire season?

5 A. The Company's situational awareness activities
6 in 2022 included refining its weather forecasting tools,
7 installing weather stations, training new personnel to
8 assist in the development and analysis of fire-season
9 weather forecasts, and initial efforts to install wildfire
10 detection cameras. Each of these activities is described in
11 more detail below.

12 Q. How much did Idaho Power's situational
13 awareness efforts cost in 2022?

14 A. The Company spent \$156,201 on situational
15 awareness in 2022.

16 Q. What is the Fire Potential Index ("FPI") and
17 how does it reduce wildfire risk?

18 A. An essential component of Idaho Power's fire
19 season work involves enhancing situational awareness by
20 forecasting the FPI. This tool, which forecasts a wildfire
21 risk level on a daily basis during fire season, supports
22 operational decision-making to reduce wildfire threats and
23 risks. For example, on days with a high FPI, automatic
24 reclosing device settings are adjusted and field personnel
25 modify work activities in Red Risk Zones.

1 The FPI tool accounts for weather, prevalence of
2 fuel (i.e., trees, shrubs, grasses), and topography, and
3 converts that data into an easily understood forecast of
4 the short-term fire threat for different geographic regions
5 in Idaho Power's service area. Additionally, the tool is
6 used to help determine when a PSPS may be necessary in
7 Idaho Power's service area.

8 The benefits of developing the FPI and enhancing the
9 Company's meteorological forecasting capabilities is
10 greater situational awareness of Idaho Power's system
11 during critical peak summer months.

12 Q. How has Idaho Power enhanced its ability to
13 forecast weather and fire conditions during wildfire
14 season?

15 A. The Company has expanded and enhanced
16 situational awareness by incorporating a new weather
17 forecasting system that leverages an ensemble of weather
18 models to improve accuracy and reduce forecast-to-forecast
19 variability. The ensemble approach also provides a measure
20 of certainty to better inform up-to-the-minute decision-
21 making for the FPI and PSPS events. As such, the new system
22 provides greater confidence in severe weather conditions
23 and will allow Idaho Power to provide early PSPS
24 notification to Public Safety Partners, operators of
25 critical facilities, and affected customers. Additional

1 personnel were leveraged to assist in the development and
2 launch of this ensemble tool.

3 **O&M: Field Personnel Practices**

4 Q. Please describe the Company's wildfire
5 mitigation efforts related to field personnel and
6 associated spending in 2022.

7 A. In 2022, the Company trained its personnel in
8 fire season conditions, practices, and operational
9 modifications. The Company equipped its field crews with
10 fire prevention tools and leveraged field observers to
11 assess on-the-ground conditions.

12 In total, the Company spent \$10,720 on mitigation
13 efforts related to field personnel in 2022.

14 Q. Why are field personnel practices vital to
15 wildfire risk reduction?

16 A. Idaho Power's field personnel and contractors
17 work across the Company's service area, including in
18 elevated risk areas. During wildfire season, the basic
19 work, routines, preparatory activities, and preparedness of
20 employees and contractors is paramount to minimizing the
21 risk of ignition events.

22 Q. What field practices did Idaho Power establish
23 for its employees and contractors during wildfire season?

24 A. Idaho Power developed a Wildland Fire
25 Preparedness and Prevention Plan to provide guidance to

1 Idaho Power employees and contractors specifically for
2 operating during wildfire season. The plan includes
3 information regarding fire season tools and equipment
4 available on the job site; daily situational awareness
5 relative to areas with heightened fire conditions; expected
6 actions and mechanisms for reducing on-the-job wildfire
7 risk as well as reporting requirements in the event of an
8 ignition; and training and compliance requirements.

9 All Idaho Power crews, and certain field personnel
10 and contractors, performing work on or near Company
11 facilities are required to operate in accordance with the
12 provisions of the Wildland Fire Preparedness and Prevention
13 Plan and expected to conduct themselves in a fire-safe
14 manner. They are also equipped for potential wildfire
15 events by carrying specific tools, including, but not
16 limited to, shovels, Pulaskis, and water for initial
17 suppression.

18 Q. What is the role of field observers during
19 wildfire season?

20 A. In its benchmarking with other utilities,
21 Idaho Power found that most utilities use field observers
22 in some capacity as part of the de-energization decision-
23 making process. The Company currently has 24 trained field
24 observers made up of Line Operations Technicians,
25 Distribution Designers, Patrolmen, and other technician

1 roles. In 2022, a PSPS event in Pocatello, Idaho was not
2 executed due to reports from field observers that rain had
3 preceded high winds. This information was not immediately
4 evident through weather stations nor available radar at the
5 time. This situation highlighted the importance of having
6 field observers equipped with mobile weather kits to inform
7 de-energization decision making.

8 ***O&M: Mitigation Efforts in the Company's T&D Programs***

9 Q. Please summarize Idaho Power's mitigation
10 activities within its T&D programs and associated O&M
11 spending in 2022.

12 A. Executing the Company's WMP relies on
13 leveraging its asset management programs to maintain safe
14 and reliable operation of T&D facilities. Specific to
15 wildfire mitigation, these efforts include: performing
16 visual and infrared thermography inspections, performing
17 maintenance based on the findings of those inspections, and
18 utilizing innovative and cost-effective approaches to
19 reduce wildfire risk, such as wrapping wood poles with a
20 fire-resistant mesh and evaluating the cost effectiveness
21 of covered conductor for potential future implementation.

22 In 2022, the Company spent \$898,966 on T&D program-
23 related wildfire mitigation efforts.

24 Q. What are the notable wildfire mitigation
25 expenses associated with Idaho Power's T&D programs?

1 A. The largest wildfire mitigation expense in the
2 Company's T&D mitigation programs is the installation of
3 fire-resistant mesh wraps. In 2022, Idaho Power spent
4 \$364,075 – or 40 percent of the total system actuals in the
5 T&D mitigation category – on fire-resistant mesh wraps. The
6 mesh, which is applied to wood transmission poles in Red
7 and Yellow Risk Zones, is an effective and widely used tool
8 to increase the resilience of the pole and improve
9 reliability for customers.

10 Q. What other T&D program activities did the
11 Company pursue in 2022 to reduce wildfire risk?

12 A. In addition to the installation of fire-
13 resistant mesh wraps, the Company conducted work associated
14 with a new Program Manager function, conducted more annual
15 inspections of its facilities in elevated risk zones,
16 expanded the use of infrared thermography inspections in
17 Red Risk Zones, launched a covered conductor pilot program,
18 and performed a variety of capital projects for which there
19 was an O&M component. Specific capital projects are
20 described in detail in the section below.

21 Q. Please describe the value and purpose of
22 thermography inspections with respect to wildfire
23 mitigation.

24 A. Infrared thermography inspections are
25 conducted using hand-held and drone-mounted cameras with

1 thermal-sensing technology and can help identify defects
2 associated with the overheating of equipment, connections,
3 splices, or conductors.

4 Thermography inspections are uniquely valuable in
5 that they can uncover problems undetectable to the naked
6 eye. From the Company's perspective, there is not a viable
7 alternative to this practice. The technology enables more
8 proactive identification of potential issues than would
9 otherwise be possible.

10 In 2022, the Company used additional personnel to
11 evaluate the annual use of thermography inspections in Red
12 Risk Zones, as opposed to the Company's historical approach
13 of periodic use of the technology across its system.

14 Q. Please explain the purpose of the covered
15 conductor pilot program.

16 A. In 2022, Idaho Power began a pilot of covered
17 conductor that will run through 2024 to explore the
18 benefits, tooling requirements for field personnel, and
19 design parameters associated with this potential mitigation
20 practice. While covered conductor may reduce the risk of
21 wildfire, the Company will analyze any other potential
22 concerns or co-benefits, including improved reliability
23 outside of wildfire season, other safety considerations,
24 and reduced outage restoration costs. Upon completion of
25 the pilot, the Company will determine whether installation

1 of covered conductor is a cost-effective risk mitigation
2 practice.

3 ***O&M: Enhanced Vegetation Management***

4 Q. What is vegetation management?

5 A. Vegetation management is the practice of
6 trimming or pruning vegetation away from the Company's
7 facilities to reduce the likelihood of vegetation coming
8 into contact with T&D lines and causing damage or an
9 outage.

10 Idaho Power has more than 400,000 trees within its
11 system that are inspected and pruned on an ongoing basis.
12 The lines are inspected periodically, and trees and
13 vegetation are cleared from the line while other trees are
14 removed entirely.

15 Q. Why is vegetation management a key part of
16 the Company's wildfire mitigation efforts?

17 A. In terms of time, expense, and overall risk
18 reduction, enhanced vegetation management is the most
19 critical aspect of executing Idaho Power's WMP. If
20 vegetation comes in contact with energized powerlines there
21 is potential that it could result in an outage or ignition.
22 Historical outage data from across Idaho Power's service
23 area shows that vegetation contact is one of the most
24 likely sources of faults and possible ignition on the power
25 system.

1 Q. What strategies has the Company employed to
2 reduce wildfire risk associated with vegetation?

3 A. Idaho Power employs an enhanced vegetation
4 management strategy in wildfire risk zones that includes
5 transitioning to a sustainable three-year pruning cycle for
6 all distribution circuits and transmission lines in valley
7 locations. In addition to achieving a three-year pruning
8 cycle, the Company conducts mid-cycle patrols and pruning
9 in the second year of the cycle to address "cycle buster"
10 trees and annual "hotspot" patrols to address any new
11 hazard trees or unexpected vegetative growth that poses an
12 immediate threat of contact with energized facilities.

13 Additionally, the Company strives to complete audits
14 for all pruning work performed in wildfire risk zones,
15 regardless of reason for the pruning. The audits confirm
16 that pruning cuts meet the specification and that the
17 proper clearance (i.e., the distance between vegetation and
18 the Company's T&D lines) was obtained.

19 Q. When developing the WMP, did the Company
20 consider different pruning cycle lengths?

21 A. Yes. The Company considered other vegetation
22 management cycle alternatives, including shorter trimming
23 cycles, longer trimming cycles, and strategies that
24 evaluate each tree individually and only trim it once it
25 has nearly grown back to the power line (known as "just-in-

1 time trimming"). Each alternative presented challenges or
2 resulted in negative impacts that undermined any potential
3 benefits. While shorter trimming cycles result in less
4 vegetation being removed during each trimming cycle, this
5 practice costs more due to the need for more resources and
6 more frequent trimming of trees near the power lines.

7 In contrast, longer cycles result in less frequent
8 trimming of each tree but larger amounts of vegetation that
9 must be removed to maintain larger clearance envelopes
10 around the power lines to accommodate additional years of
11 vegetative growth. Further, longer trimming cycles create
12 logistical challenges that are exacerbated by tree biology.
13 Some trees simply grow faster than a given trimming cycle
14 and the longer the trimming cycle, the more pervasive this
15 issue becomes. Longer cycles that call for heavy pruning
16 also lead to hormonal imbalances between a tree's canopy
17 and its root system. To correct this imbalance, the tree
18 aggressively re-grows new sprouts to quickly replace its
19 lost canopy. In this regard, heavier pruning results in a
20 faster rate of tree regrowth than normal, making it even
21 more difficult to consistently maintain longer trimming
22 cycles.

23 Finally, "just-in-time trimming" is primarily a
24 reactive strategy that ultimately leads to challenges
25 associated with securing qualified tree-trimming crews, as

1 this ad hoc approach involves hiring crews on an as-needed
2 basis rather than on a consistent schedule.

3 After evaluating these alternative approaches, Idaho
4 Power concluded that maintaining a three-year trimming
5 cycle is the most cost-effective and sustainable strategy
6 to keep vegetation away from power lines in a proactive
7 manner.

8 Q. How has shifting to a three-year cycle and
9 implementing other enhanced vegetation management
10 activities affected costs?

11 A. Moving to a three-year vegetation management
12 cycle and performing enhanced vegetation activities –
13 including pre-season patrols, additional inspections, pole
14 clearing, tree and shrub removal, and quality assurance in
15 Red and Yellow Risk Zones – has resulted in a sizeable
16 increase in O&M expenditure. In 2022, Idaho Power spent
17 \$25,151,422 on vegetation management – more than double the
18 \$10.7 million of vegetation management expense in 2019 –
19 and representing the single largest source of the Company's
20 wildfire-related expenditure. The Company's second largest
21 source of wildfire-related expenditure is insurance, which
22 is addressed in Mr. Buckham's testimony.

23 Q. Why has the Company experienced such
24 substantial growth in the cost of vegetation management?

1 A. A variety of factors help explain the cost
2 increases Idaho Power has experienced to perform vegetation
3 management. Most notably, the availability of qualified
4 labor has diminished while demand for vegetation management
5 services has grown across the western US among other
6 utilities, other industries, and government agencies that
7 also recognize vegetation management is a critical
8 component of wildfire risk mitigation.

9 Importantly, the vegetation management companies
10 hired by Idaho Power and other utilities are not simple
11 arborists or landscapers. Rather, vegetation management
12 companies qualified to work near electrical lines and
13 equipment require special certifications and training. The
14 limited number of companies offering such qualified
15 services are in high demand in many western states and
16 especially in California, where labor rates are higher for
17 the work itself and the labor that provides it. Idaho Power
18 has felt the effect of out-of-state competition in the form
19 of double-digit cost increases and qualified labor
20 shortages.

21 Another exacerbating factor of vegetation management
22 cost is Idaho's growth. Greater population density and
23 expansion of homes into more vegetation-dense areas has
24 made it harder to maintain a consistent vegetation
25 management cycle. New development is routinely built with

1 frontage trees and other vegetation. The growth in newly
2 planted trees certainly leads to more work, but an
3 associated problem is that these trees are often
4 inappropriate for their location and environment. Trees
5 that grow wide and tall and/or mature quickly are poor
6 candidates for planting near or beneath electrical lines,
7 and yet tree selection is more often made based on
8 aesthetics rather than safety. This problem persists
9 despite Idaho Power making significant efforts to
10 communicate and educate on appropriate tree selection in
11 several ways, including the "Right Tree, Right Place" tree
12 planting guide, which offers detailed information on
13 selecting appropriate trees and planting them at safe
14 distances from power lines.

15 Finally, climate change is a factor contributing to
16 escalating vegetation management costs. In recent years,
17 Idaho has experienced wetter springs followed by more
18 temperate summers and falls, leading to longer vegetation
19 growing seasons.

20 Another climate-related issue is the spread of pests
21 such as the bark beetle that leave dead trees in their
22 wake. Failure to remove dead or dying vegetation - a
23 problem felt most acutely on government land - complicates
24 vegetation management work and makes adhering to a routine

1 clearing cycle more challenging, time consuming, and,
2 thereby, more costly.

3 Q. Has the Company explored any alternatives to
4 vegetation management?

5 A. Yes. The primary alternative to vegetation
6 management is converting overhead distribution circuits to
7 underground. However, undergrounding is consistently more
8 expensive than enhanced vegetation management. The Company
9 continues to evaluate and implement underground solutions,
10 as appropriate and cost-effective based on risk, as part of
11 its WMP hardening efforts, as described in the section
12 below.

13 Q. Has the Company identified benefits other than
14 risk reduction from enhanced vegetation management
15 practices?

16 A. Yes. Although vegetation management is a
17 sizeable increased wildfire mitigation expense, performing
18 this work is expected to have notable co-benefits,
19 including reduced vegetation-caused outages, thereby
20 enhanced reliability, in Red and Yellow Risk Zones. Idaho
21 Power plans to monitor performance and outage metrics to
22 confirm the success of the enhanced program. Decreasing
23 vegetation outages was considered one of the most
24 important, cost-effective measures Idaho Power could take

1 to reduce the likelihood of an ignition event and protect
2 utility infrastructure.

3 Q. Is Idaho Power's enhanced vegetation
4 management program prudent and in customers' best interest?

5 A. Yes. Shifting to enhanced vegetation
6 management practices, including the move to a three-year
7 pruning cycle, was deemed a prudent course of action based
8 on the reduction of risk in wildfire risk zones and the
9 number of potential outages or ignition sources that may be
10 eliminated. A vegetation management-focused wildfire
11 mitigation program is also the approach adopted by many of
12 Idaho Power's peer utilities.

13 Q. Has the Company evaluated new technology to
14 help in vegetation management efforts and reduce
15 vegetation-related risks?

16 A. Yes. Vegetation monitoring tools have come to
17 market in recent years that have the potential to help
18 Idaho Power apply a more targeted approach to vegetation
19 management. The Company conducted a pilot effort in 2022
20 that involved combining artificial intelligence ("AI") with
21 satellite and aerial imagery surveys of overhead powerlines
22 to detect vegetation encroachment and hazard trees.

23 The surveys have the potential to identify problem
24 areas more quickly than conventional methods and provide
25 less reliance on "eyes on the ground" to identify areas at

1 risk of vegetation contact or trees in poor health that may
2 fall into powerlines. In addition, the technology has the
3 potential to allow Idaho Power to invest resources where
4 they will be the most effective in mitigating the impact of
5 wildfires.

6 Q. What were the results of the pilot?

7 A. Initial results of the pilot did not
8 demonstrate sufficient accuracy needed to make risk-
9 informed decisions for vegetation encroachment.

10 Q. Will the pilot shift Idaho Power's approach to
11 vegetation management?

12 A. Perhaps. The Company plans to reassess the
13 technology in 3 to 5 years as improvements in machine
14 learning and AI are made.

15 Q. What is Idaho Power's assessment of the need
16 for ongoing enhanced vegetation management?

17 A. Based on comparison to underground conversions
18 and the insufficiency of current technology to allow a more
19 targeted approach to vegetation management, Idaho Power
20 considers its strategy of achieving and maintaining a
21 three-year pruning cycling, along with enhanced practices
22 in Red and Yellow Risk Zones, the most prudent approach for
23 reducing wildfire risk associated with vegetation.

24 Considering the challenges noted above, the Company
25 expects vegetation management expense may continue to rise.

1 A discussion of this concern, and the associated
2 justification for ongoing vegetation management cost
3 deferral at a new baseline level, is provided in the Direct
4 Testimony of Company Witness Mr. Timothy Tatum.

5 ***O&M: Communications & Information Technology***

6 Q. Please explain the Company's communication and
7 information technology-related strategies in the WMP.

8 A. The Company conducts several education
9 campaigns around wildfire each year, including promoting
10 the Company's wildfire mitigation activities and work
11 within communities, providing awareness and education on
12 how to prepare for wildfire season. The following core
13 messages are the foundation for all wildfire-related
14 communications each year:

15 • How customers can prepare for wildfire-related
16 outages, including where to find outage and PSPS
17 information and how to sign up for alerts and update
18 contact information;

19 • Ways customers can reduce wildfire risk; and
20 • Idaho Power's work to protect the grid from
21 wildfire and reduce wildfire risk.

22 Idaho Power communicates with customers and the
23 public before and throughout wildfire season to inform them
24 of steps the Company is taking to reduce wildfire risk and
25 ways they can help prevent wildfires and prepare for

1 outages. Various communication mediums used to accomplish
2 this include: newsletters, news media, website content and
3 videos, social media, postcards, and paid advertising.

4 The Company also promotes ways that the public can
5 reduce the potential to ignite fires. Customers in PSPS
6 zones are targeted for expanded communication to promote an
7 awareness of PSPS and outage preparation. PSPS-focused
8 communication comes in the form of advertisements, bill
9 inserts, postcards, and other awareness raising and
10 educational campaigns.

11 Q. What efforts has the Company made to
12 directly contact customers about emergency events and
13 outages?

14 A. To help provide timely communication of
15 emergency events – specifically, PSPS – to customers, the
16 Company has implemented a communication tool called the
17 Enterprise Omnichannel Notification System (“EONS”). Having
18 advanced alerts prior to and during a PSPS is an important
19 aspect of Idaho Power’s PSPS program. A large component of
20 the EONS tool is identifying critical customers and
21 facilities that will automatically be contacted leading up
22 to, during, and after a PSPS event.

23 Q. What did the Company spend in 2022 on
24 customer communication and related information technology?

1 A. In 2022, Idaho Power spent \$106,779 on
2 communications to customers and communities before, during,
3 and after wildfire season. This amount includes postcards
4 sent to all customers in PSPS zones to educate them about
5 the purpose of PSPS and how they can stay connected to the
6 Company to learn about PSPS events.

7 Implementing the EONS system, a critical tool for
8 more timely communication with customers, cost \$80,531 in
9 2022.

10 ***Wildfire Mitigation Capital Investments***

11 Q. In what capital projects has the Company
12 invested related to wildfire mitigation?

13 A. The table below summarizes wildfire
14 mitigation investments by mitigation program:

15 //

16 //

17

18

19

20

21

22

23

24

25

1 **TABLE 2**
 2 CAPITAL INVESTMENT BASED ON PLANT CLOSINGS IN 2021 AND 2022
 3

Mitigation Program	Description of the Program	Risk Reduction Benefit	Plant Closings in 2021 and 2022
Overhead Primary Hardening Program	Systematic replacement of hardware, equipment, and materials, 113-line miles in Red Risk Zones	Reduced potential of equipment failure, utilizing material and equipment with less energy release and potential of ignition, increased resiliency	\$9,869,070
Strategic Undergrounding	Select conversion of overhead to underground conversion in Red Risk Zones, 1.85 miles completed in 2022	Reduce exposure and potential of ignition by locating power lines underground	\$1,822,482
Red Risk Zone Overcurrent Protection Segmentation	Installation, relocation, and expanded communication for Automatic Reclosing overcurrent protection devices	Isolate circuit segments and improve reliability for enhanced Fire Potential Index settings and PSPS	\$367,899

4
 5 Q. What is included in the Overhead Primary
 6 Hardening Program?

7 A. The Overhead Distribution Hardening program
 8 involves systematic replacement of hardware, equipment, and

1 materials to improve safety and reliability and reduce
2 ignition risk. The program is targeted for Red Risk Zones.
3 Enhanced measures to mitigate wildfire are:

4 **Wood Pole Replacement**—The Company will replace wood
5 poles if field evaluations determine that significant
6 deterioration or damage has occurred since the last
7 inspection or treatment. Furthermore, poles having wood
8 stubs/structural reinforcements are changed out pursuant to
9 current practices.

10 **Spark Prevention Units**—Porcelain arresters used for
11 overvoltage protection will be changed out with arresters
12 utilizing Spark Prevention Units ("SPU"). The SPU acts to
13 eliminate the potential of catastrophic failure during
14 arrester operation.

15 **Fiberglass Crossarms**—Replacing wood tangent and
16 dead-end crossarms with fiberglass. Fiberglass crossarms
17 provide decrease the likelihood of heating through a
18 crossarms and cross-functional benefits of lower cost, ease
19 of installation, strength, and supply availability.

20 **Small Conductor**—Replace copper conductor and
21 conductor smaller than #4 Aluminum Conductor Steel
22 Reinforced.

23 **Porcelain Switches**—All porcelain switches installed
24 in Red Risk Zones will be changed out with cutouts
25 featuring Ethylene Propylene Diene Monomer Rubber.

1 **Avian Protection Coverings**—Idaho Power employs
2 several different protection measures to protect wildlife
3 on existing structures, including but not limited to
4 covers, insulated conductor, diverters, perches, nesting
5 platforms, and structural modifications.

6 In addition to the enhanced hardening measures
7 mentioned above, each location is inspected to ensure
8 structures and equipment are brought up to current
9 construction standards. All existing hardware that will
10 remain in place is re-tightened, loose conductors are re-
11 tensioned, and third-party pole attachments are checked for
12 proper clearances.

13 Q. Does hardening work occur on the transmission
14 system?

15 A. Yes. On the transmission side, the Company
16 evaluates upcoming transmission line construction projects-
17 such as new line construction and line rebuilds with the
18 plan to use steel construction for all lines of 138 kV and
19 above. For existing wood poles, a fire-resistant mesh wrap
20 is applied to existing wood poles in designated wildfire
21 risk zones, as discussed earlier in my testimony. The mesh
22 wrap improves the resiliency of the pole and keeps it from
23 catching fire if exposed to a surface fire.

1 Q. What steps did the Company take to determine
2 what mitigation measures should be included in the
3 hardening program?

4 A. Idaho Power researched historical faults on
5 the T&D system to determine outage causes that may result
6 in potential ignition. That analysis determined that
7 tree/vegetation contact, equipment failure, loose hardware,
8 corrosion, and animal contact are among the top causes of
9 faults throughout the service area. Specific risk drivers
10 were established and identified as part of the risk
11 evaluation process.

12 In addition, the Company used the Cal Fire Powerline
13 Fire Prevention Guide to help identify equipment and
14 materials that may contribute or cause an ignition on the
15 power system. This guide, combined with the Company's past
16 root cause analysis and feedback from employees with line
17 construction and maintenance experience, helped identify
18 expulsion fuses, porcelain switches, deteriorated wood
19 crossarms, expulsion arresters, and small conductor as
20 being potential ignition sources.

21 Q. Does the hardening program offer any co-
22 benefits for customers?

23 A. Yes. The Overhead Distribution Hardening
24 program includes infrastructure upgrades and the
25 replacement of several materials or equipment to reduce the

1 likelihood of ignition on the distribution system. Each
2 material or equipment selected was analyzed to determine
3 its effectiveness at reducing risk, estimated near-term
4 cost, potential co-benefits of the activity to Idaho Power
5 and its customers, and costs between alternatives. At a
6 foundational level, the program offers the co-benefit of
7 improved reliability for customers and a decrease of
8 ignition potential.

9 Q. Can reliability indices be used to measure the
10 effectiveness of the hardening program?

11 A. Yes. Prior to developing the WMP, Idaho Power
12 successfully implemented distribution hardening measures
13 and, through outage data and analytics over that period
14 (2010 through 2019), learned that customer outages were
15 reduced by approximately 38 percent in areas where
16 reliability hardening projects were carried out. This
17 initial success of reducing outages for reliability
18 purposes resulted in the Company selecting similar
19 activities in the WMP to further increase reliability and
20 help reduce ignition potential in Red Risk Zones. Idaho
21 Power is tracking reliability performance in wildfire risk
22 zones over time to assess effectiveness.

23 Q. What is the Strategic Undergrounding Program?

24 A. As part of Idaho Power's effort to reduce
25 wildfire risk and impacts associated with outages and PSPS,

1 Idaho Power evaluates the cost-effectiveness of overhead-
2 to-underground conversion of distribution lines on a case-
3 by-case basis.

4 Areas selected for conversion will have increased
5 reliability and resiliency to wildfire, and customers in
6 the area will no longer be exposed to the potential of long
7 outages associated with operational protection settings on
8 high fire potential days or PSPS. Strategic Undergrounding,
9 one effort of many the Company is taking to reduce wildfire
10 risk, is selected in highest-risk areas when the cost-
11 benefit analysis shows that underground construction is
12 prudent.

13 Q. Has the Company completed any underground
14 conversion projects for wildfire mitigation?

15 A. Yes. In 2022, overhead-to-underground
16 conversion was performed on 1.85 miles of distribution
17 lines in Idaho. The projects included four line segments on
18 the Boise Bench and Cartwright feeders in Boise, Idaho.
19 These were the first underground conversion projects that
20 the Company has undertaken to reduce wildfire risk.

21 Q. Why were the locations selected for
22 underground conversion?

23 A. The areas were chosen for underground
24 conversion due to the results of risk quantification and
25 work, summarized later in my testimony. That work

1 identified the areas having a combination of high wildfire
2 probability and impacts to structures.

3 Field assessments and feedback from local fire
4 officials confirmed that the topography and surface fuels
5 in the areas were conducive to rapid fire spread, which
6 could lead to structure and human safety impacts.

7 Fire history was another factor considered for the
8 project near Idaho Power's Boise Bench Substation, located
9 off Amity Road in East Boise. Another consideration was
10 that the undergrounding of these line segments would
11 decrease the overall risk profile of each feeder due to
12 most of the feeders already having underground
13 distribution.

14 Q. What criteria did the Company use to select
15 the underground conversion projects?

16 A. The Overhead Distribution Hardening program is
17 the primary program used to decrease the likelihood of
18 ignition on the distribution system. Underground conversion
19 projects are undertaken for locations where outage data and
20 risk assessments show the need for increased risk reduction
21 beyond what the hardening program provides.

22 Idaho Power's approach to selecting underground
23 conversion projects involves the ISO 31000 risk management
24 framework. Established criteria used in the assessment for
25 optimal underground conversion locations is as follows:

- 1 • Wildfire risk modeling scores, having high
2 wildfire probability and impacts to structures;
- 3 • Fire history where distribution overhead circuits
4 may be susceptible to repeat wildfire events over their
5 lifetime;
- 6 • Areas having a high likelihood of ignition due to
7 risk drivers such as vegetation contact, contact from
8 objects, lightning, and equipment failure;
- 9 • PSPS zones having high likelihood of proactive
10 de-energization due to historic weather patterns,
11 vegetation, or ignition risk;
- 12 • Areas of high wildfire risk that present
13 challenges to patrol due to access issues, terrain, or
14 inability to perform aerial inspections after a PSPS or
15 outages on days with high FPI; and
- 16 • Areas where PSPS and enhanced protection settings
17 may impact critical infrastructure.

18 The underground conversion projects in 2022 were
19 analyzed by their expected risk-reduction benefit to
20 overall project cost. And, for the projects in question,
21 underground conversion was deemed cost-effective based on
22 the level of risk reduction and type of risk driver that
23 was mitigated.

24 Q. How do the costs of overhead distribution
25 hardening compare to underground conversions?

1 A. The cost of converting overhead distribution
2 lines to underground can vary significantly based on the
3 voltage level, equipment, and terrain to be worked. The
4 2022 underground conversion projects cost \$1,822,482 – or an
5 average cost of \$985,125 per line mile. The benefit of the
6 projects are increased wildfire resiliency and decreased
7 potential of ignition. Based on wildfire modeling and
8 property values⁸ in the area, Idaho Power estimates that the
9 project is protecting structures that could cost upwards of
10 \$45 million to replace in the event of a destructive
11 wildfire.

12 Q. What is the Overcurrent Protection
13 Segmentation program?

14 A. The Overcurrent Protection Segmentation
15 program involves the installation of automatic reclosing
16 equipment (“reclosers”) at the edge of Red Risk and PSPS
17 zones. By strategically locating reclosers at the edge of a
18 zone, the Company can limit the impact on customers outside
19 of those zones from increased outages due to enhanced
20 protection settings on days with high fire potential and
21 PSPS. The program also includes adding communication
22 capabilities to recloser so they can be remotely operated
23 through the Company’s dispatch group. The remote operation

⁸ 2022 median home prices as reported by the Ada County Assessor’s Office.

1 provides the benefit of being able to change protection
2 settings remotely on days when the FPI is high. It also
3 gives Reliability Engineers the ability to assess waveforms
4 and fault characteristics immediately after a fault occurs,
5 eliminating the need for a technician to travel and
6 download the event record.

7 **2022 WMP Performance**

8 Q. What metrics is the Company tracking to gauge
9 the effectiveness of the WMP?

10 A. Idaho Power tracks several metrics to measure
11 the performance of the WMP and its effectiveness over time.
12 Each year, work plans are established at the beginning of
13 the year and items are tracked throughout the year to
14 identify areas needing corrective action or attention. This
15 includes monitoring vegetation management activities,
16 inspections, and circuit hardening. Idaho Power's goal is
17 to complete 100 percent of the work plan each year;
18 however, emergencies or other unplanned events can occur
19 and disrupt the annual work plan.

20 Q. How did Idaho Power perform on its WMP
21 wildfire mitigation objectives in 2022?

22 A. As is demonstrated in the table below, the
23 Company met or exceeded its wildfire mitigation objectives
24 in 2022, in all but two instances.

25 //

1 **TABLE 3**
 2 2022 WMP PERFORMANCE METRICS

Plan Area	Wildfire Mitigation Plan Activities	2022 Goal	Completed	% Complete	2023 Goal
System Hardening	Distribution System Hardening				
	System Hardening Line Miles	48	48.91*	102%	69
	Overhead Line Miles Converted to Underground	1.85	1.85	100%	1
	Expulsion Fuse Replacement	930	942	101%	1319
Feeder Segmentation	Surge Arrester Replacement	830	839	101%	1175
	Segmentation Devices				
Fire Mesh Installation	Installation or Relocation of Automatic Reclosing Devices	17	17	100%	8
	Transmission Fire Mesh Installation				
	Red Risk Zone Poles	492	492	100%	-
Asset Inspections	Yellow Risk Zone Poles	406	585	144%	870
	Transmission Inspections				
	Wildfire Pre-Season Patrol - Red Risk Zones (Structures)	923	923	100%	923
	Infrared Thermography Patrol (Structures)	923	923	100%	923
	Distribution Inspections				
	Wildfire Pre-Season Patrol - Red Risk Zones (Structures)	20,192	20,192	100%	20,192
Vegetation Management	Infrared Thermography Patrol - Red Risk Zones (Structures)	3,000	3,800	127%	4,000
	Pruning Cycle				
	Transition to a 3-Year Pruning Cycle (circuits)	282	173	70%**	320
	Enhanced Vegetation Management				
	Annual Patrol - Red & Yellow Risk Zones (circuits)	65	65	100%	65
	Annual Mitigation - Red & Yellow Risk Zones (circuits)	65	65	100%	65
	Mid-Cycle Patrols - Red & Yellow Risk Zones (circuits)	47	47	100%	1
	Mid-Cycle Pruning - Red & Yellow Risk Zones (circuits)	47	47	100%	1
Meteorology	Hazard Trees Identified and Pruned	-	77	100%	100% of All Identified
	Hazard Trees Identified and Removed	-	49	100%	100% of All Identified
	Audits of Pruning Activities - Red & Yellow Risk Zones (worksites)	6,324	977	15%**	100% of All Identified
	Idaho Power Weather Stations				
Weather Station Installations	5	5	100%	5	

*Excludes hardening work outside of wildfire risk zones

**Estimated year end completion

3
 4 The Company did not fully achieve its 2022
 5 vegetation management production goal in the transition to
 6 a three-year vegetation management cycle and, similarly,
 7 fell below the goal with respect to pruning audits in high-
 8 risk zones. Both of these outcomes are the direct result of
 9 the vegetation management challenges discussed earlier in
 10 my testimony – namely, labor shortages that have made it
 11 difficult to hire enough qualified crews to perform the
 12 Company’s needed vegetation management work.

13 Q. Please summarize your testimony in this
 14 case.

1 A. As evidenced by the Company's ongoing
2 improvement in reliability metrics, Idaho Power has taken a
3 thoughtful and prudent approach to construction and
4 maintenance of its T&D systems.

5 Regarding wildfire mitigation, the Company made
6 substantial and prudent 2022 investments in programs,
7 personnel, infrastructure, system hardening, and vegetation
8 management to ensure that Idaho Power can continue to
9 safely and reliably serve customers and continue to make
10 great strides to mitigate wildfire risk.

11 Q. Does this conclude your direct testimony in
12 this case?

13 A. Yes, it does.

14 //

15 //

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DECLARATION OF MITCH COLBURN

I, Mitch Colburn, declare under penalty of perjury under the laws of the state of Idaho:

1. My name is Mitch Colburn. I am employed by Idaho Power Company as the Vice President of Planning, Engineering, and Construction.

2. On behalf of Idaho Power, I present this pre-filed direct testimony and Exhibit Nos. 4 through 5 in this matter.

3. To the best of my knowledge, my pre-filed direct testimony and exhibits are true and accurate.

I hereby declare that the above statement is true to the best of my knowledge and belief, and that I understand it is made for use as evidence before the Idaho Public Utilities Commission and is subject to penalty for perjury.

SIGNED this 1st day of June 2023, at Boise, Idaho.

Signed 
MITCH COLBURN