

# Idaho PUC Pipeline Safety Inspection Summary

<b>Inspector(s):</b>	Perkins	<b>Date(s):</b>	23-Jun-20
<b>Company/Owner:</b>	Intermountain Gas Company	<b>Unit/OPID:</b>	8160
<b>Inspection Type &amp; Time (1 day)</b>	<b>Total Inspection Days:</b>		1
Standard: <input type="checkbox"/>	Construction: <input checked="" type="checkbox"/> 1	Training: <input type="checkbox"/>	(T)(D) Integrity Management: <input type="checkbox"/> Incident: <input type="checkbox"/>
M/M: <input type="checkbox"/>	Follow-up: <input type="checkbox"/>	OQ: <input type="checkbox"/>	Damage Prevention: <input type="checkbox"/> D&A: <input type="checkbox"/>
<b>Inspection Summary</b>			

A construction inspection was performed on Das-co, a contractor for Intermountain Gas Company.

**23 June 2020:** (1.0 Construction)

Observed a Das-co crew extending 2" main approximately 60' and installing new 3/4" service to 26 N Joseph, Nampa, Idaho. All procedures were followed. Typed up report



Areas observed during this project were: Excavating, line locating, service line install, pressure testing, backfilling, met-fit couplings, pot holing and boring.

**Attachments:**

IPUC Form 4 Construction Inspections

Das-co daily Itineraries located in file for the project.

OQ's for all observed employees are located in file for the project.

<b>Corrective Action Required:</b>	<b>Follow-up Required:</b>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	by (date):	
Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>					
<b>Inspector (Lead):</b>			<b>Date:</b>		
Bruce Perkins			6/23/2020		
<b>Reviewer:</b>			<b>Date:</b>		
Darrin Ulmer			24 June 2020		