


SNAKE RIVER OIL + GAS



RECEIVED

APR -7 AM 11:02

IDAHO PUBLIC
UTILITIES COMMISSION

Phone Number
870-234-3080

P.O. Box 500
Magnolia, Arkansas 71754-0500

Fax Number
870-234-3839

Attention: Darrin Ulmer

4-1-2020

From: Nate Caldwell
Northwest Gas Processing
Subject: Letter of Concern
Report # N202001

Hello Darrin,

In regard to your recently received letter of concern,

#1 We are currently abiding by the manual that was comprised by the previous operator. We're currently modifying and updating to fall in line with our procedures.

#2 After being addressed, we began pre-heating to 200 degrees F with Temperature sticks when ambient temps were below 50 degrees F. A welding inspector was present during the entire job.

Should you have any questions or concerns, please feel free to contact me anytime.

Truly yours,

Nate Caldwell