



RECEIVED

2007 FEB 23 PM 2:05

IDAHO PUBLIC  
UTILITIES COMMISSION

**BARTON L. KLINE**  
Senior Attorney

February 23, 2007

Jean D. Jewell, Secretary  
Idaho Public Utilities Commission  
472 West Washington Street  
P. O. Box 83720  
Boise, Idaho 83720-0074

Re: Case No. IPC-E-05-37  
Idaho Power Company Agreement to Provide Standby Electric Service  
To The Amalgamated Sugar Company, LLC

Dear Ms. Jewell:

In Order No. 29958 issued on January 26, 2006 in Case No. IPC-E-05-37 the Commission approved a Revised Standby Service Agreement ("Agreement") between Idaho Power and Amalgamated Sugar Company ("TASCO") dated December 7, 2005. Under the Agreement Idaho Power supplies standby electric service to TASCO. In Order No. 29958 the Commission referenced the Uniform Service Agreements under which Idaho Power provides demand and energy to TASCO's Nampa, Twin Falls and Paul facilities.

Since the issuance of Order No. 29958, TASCO has increased the supplemental contract demand amounts at the Nampa, Paul and Twin Falls facilities. As a result, it is necessary to amend Section 4.4 of the Agreement to reflect the total contract demand now requested by TASCO.

Enclosed for filing is a letter agreement dated January 31, 2007 in which Idaho Power and TASCO have agreed to amend the Agreement to reflect the increased total contract demand now requested by TASCO. I would request that you file the Letter Agreement with the Agreement that was approved in the IPC-E-05-37 case. It is not Idaho Power Company's intention to file an application with the Commission and open a new docket for a contract change that is in the nature of a housekeeping matter. I have discussed this matter with Mr. Woodbury. Of course, if the Commission desires that Idaho Power make a separate filing to present this amendment, the Company is certainly willing to do so.

Jean Jewell  
February 23, 2007  
Page 2

If the Commission has any questions regarding this matter please do not hesitate to contact me.

Very truly yours,

A handwritten signature in black ink, appearing to read 'B. Kline', with a long horizontal flourish extending to the right.

Barton L. Kline

BLK:jb

Enclosures

cc: Scott Woodbury  
K. Peter Chertudi  
Jim Hovda  
Mike Pohanka  
Ric Gale  
Maggie Brilz

IPC-E-05-37

Letter Agreement



**IDAHO  
POWER®**

An IDACORP Company

IDAHO POWER COMPANY  
P.O. BOX 70  
BOISE, IDAHO 83707

JOHN R. GALE  
Vice President  
Regulatory Affairs

(208) 388-2887  
FAX (208) 388-6449  
E-MAIL rgale@idahopower.com

January 31, 2007

Mr. K. Peter Chertudi  
Senior Vice President  
The Amalgamated Sugar Company, LLC  
3184 Elder Street  
Boise, Idaho 83705

Dear Mr. Chertudi:

The Agreement for Supply of Standby Electric Service between Idaho Power Company ("the Company") and The Amalgamated Sugar Company, LLC ("TASCO") dated December 7, 2005 ("the Agreement") provides up to three megawatts of standby service on a uniform basis to your Nampa, Twin Falls, and Paul facilities in Idaho.


Because TASCO has increased the Supplemental Contract Demand amounts at the Nampa, Paul, and Twin Falls facilities through the Uniform Service Agreement for each of the facilities, it is necessary to amend Section 4.4 of the Agreement to provide the Total Contract Demand now requested by TASCO. Accordingly, the Agreement is to be amended as follows:

1. Paragraph 4.4 will be amended to read:
 

<i>Nampa Facility</i> .....	<i>13,500 kW</i>
<i>Paul Facility</i> .....	<i>18,000 kW</i>
<i>Twin Falls Facility</i> .....	<i>8,500 kW</i>
in lieu of	
<i>Nampa Facility</i> .....	<i>10,500 kW</i>
<i>Paul Facility</i> .....	<i>13,000 kW</i>
<i>Twin Falls Facility</i> .....	<i>7,500 kW</i>

If you approve of the foregoing amendments to the December 7, 2005 Agreement, please indicate your acceptance in the space provided below, retain one copy of this Letter Agreement and return a copy for our files.

Cordially,

  
John R. Gale

JRG:ma  
Enclosures

The Above Letter Agreement Read,  
Understood, and Agreed to:

Date: Feb 2, 2007

By: 

Its: Senior Vice President